

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2349383 Test Start : 02/08/2016 @ 13:52
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:38
Location : First Floor-Music 121 Received: 02/17/2016 @ 15:17
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 11:44
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2349391 Test Start : 02/08/2016 @ 13:26
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:20
Location : First Floor-96 Received: 02/17/2016 @ 15:17
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 12:18
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2349400 Test Start : 02/08/2016 @ 13:46
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:36
Location : First Floor-113B Stor Received: 02/17/2016 @ 15:17
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 10:20
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2349401 Test Start : 02/08/2016 @ 13:33
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:25
Location : First Floor-104 Received: 02/17/2016 @ 15:17
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 14:31
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2349473 Test Start : 02/08/2016 @ 13:33
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:25
Location : First Floor-104 Received: 02/17/2016 @ 15:17
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 12:35

Average of Side by Side Canisters 0.6 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2349593 Test Start : 02/08/2016 @ 13:30
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:24
Location : First Floor-E1-Stor Received: 02/17/2016 @ 15:17
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 10:20



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2349594
Canister Type : Charcoal Canister 3 inch
Location : First Floor-114/A/B
Radon Level : 0.9 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/08/2016 @ 13:41
Test Stop : 02/11/2016 @ 14:32
Received: 02/17/2016 @ 15:17
Analyzed: 02/18/2016 @ 13:54

Canister ID# : 2349603
Canister Type : Charcoal Canister 3 inch
Location : First Floor-Cafe
Radon Level : 1.1 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/08/2016 @ 13:54
Test Stop : 02/11/2016 @ 14:39
Received: 02/17/2016 @ 15:17
Analyzed: 02/18/2016 @ 12:00

Canister ID# : 2349604
Canister Type : Charcoal Canister 3 inch
Location : First Floor-106
Radon Level : 0.7 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/08/2016 @ 13:32
Test Stop : 02/11/2016 @ 14:25
Received: 02/17/2016 @ 15:17
Analyzed: 02/18/2016 @ 09:22

Canister ID# : 2350056
Canister Type : Charcoal Canister 3 inch
Location : First Floor-121A Off
Radon Level : 1.4 pCi/L
Error for Measurement is: \pm 0.7 pCi/L

Test Start : 02/08/2016 @ 13:51
Test Stop : 02/11/2016 @ 14:38
Received: 02/17/2016 @ 15:17
Analyzed: 02/18/2016 @ 12:18

Canister ID# : 2350060
Canister Type : Charcoal Canister 3 inch
Location : First Floor-Princ Off
Radon Level : 0.6 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/08/2016 @ 13:20
Test Stop : 02/11/2016 @ 14:16
Received: 02/17/2016 @ 15:17
Analyzed: 02/18/2016 @ 09:22

Canister ID# : 2350065
Canister Type : Charcoal Canister 3 inch
Location : First Floor-120
Radon Level : 0.5 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/08/2016 @ 13:45
Test Stop : 02/11/2016 @ 14:35
Received: 02/17/2016 @ 15:17
Analyzed: 02/18/2016 @ 09:40



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2350066 Test Start : 02/08/2016 @ 13:38
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:27
Location : First Floor-101 Received: 02/17/2016 @ 15:17
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2354677 Test Start : 02/08/2016 @ 13:56
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:41
Location : First Floor-Kitchen Off Received: 02/17/2016 @ 15:17
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 09:40
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2355062 Test Start : 02/08/2016 @ 13:27
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:22
Location : First Floor-100 Received: 02/17/2016 @ 15:17
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 09:40
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2356592 Test Start : 02/08/2016 @ 13:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:29
Location : First Floor-111 Received: 02/17/2016 @ 15:17
Radon Level : 0.6 pCi/L Analyzed: 02/17/2016 @ 17:21
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2356605 Test Start : 02/08/2016 @ 13:22
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:17
Location : First Floor-98A Received: 02/17/2016 @ 15:17
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 11:28
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2360355 Test Start : 02/08/2016 @ 13:54
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:40
Location : First Floor-Copy 122B Received: 02/17/2016 @ 15:17
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 11:44
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2360356 Test Start : 02/08/2016 @ 13:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:18
Location : First Floor-97B Received: 02/17/2016 @ 15:17
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 09:40
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2360407 Test Start : 02/08/2016 @ 13:43
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:34
Location : First Floor-117 Received: 02/17/2016 @ 15:17
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 09:57
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2360412 Test Start : 02/08/2016 @ 13:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:37
Location : First Floor-121G Off Received: 02/17/2016 @ 15:17
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 12:18
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2360413 Test Start : 02/08/2016 @ 14:03
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:49
Location : First Floor-202 Received: 02/17/2016 @ 15:18
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 12:00
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2360416 Test Start : 02/08/2016 @ 14:05
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:52
Location : First Floor-200B Received: 02/17/2016 @ 15:18
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 12:18
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2360423 Test Start : 02/08/2016 @ 14:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:55
Location : First Floor-Boy Locker Rm Received: 02/17/2016 @ 15:18
Radon Level : 0.8 pCi/L Analyzed: 02/17/2016 @ 17:40
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2360428 Test Start : 02/08/2016 @ 13:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:27
Location : First Floor-102 Received: 02/17/2016 @ 15:17
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 12:00
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2360703 Test Start : 02/08/2016 @ 13:21
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:16
Location : First Floor-99 Received: 02/17/2016 @ 15:17
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 11:28
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2360704 Test Start : 02/08/2016 @ 13:19
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:15
Location : First Floor-VP Off Received: 02/17/2016 @ 15:17
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 11:44
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361255 Test Start : 02/08/2016 @ 13:24
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:18
Location : First Floor-97A Received: 02/17/2016 @ 15:17
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 10:20
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2362126 Test Start : 02/08/2016 @ 13:22
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:17
Location : First Floor-98B Received: 02/17/2016 @ 15:17
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 12:18
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2366136 Test Start : 02/08/2016 @ 14:12
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:57
Location : First Floor-209 Received: 02/17/2016 @ 15:18
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 11:28
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2366139 Test Start : 02/08/2016 @ 14:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:54
Location : First Floor-Gym Received: 02/17/2016 @ 15:18
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366146 Test Start : 02/08/2016 @ 14:06
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:51
Location : First Floor-200A Cust Received: 02/17/2016 @ 15:18
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 09:57
Error for Measurement is: \pm No Result

Canister ID# : 2366147 Test Start : 02/08/2016 @ 14:03
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:49
Location : First Floor-202 Received: 02/17/2016 @ 15:18
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 09:40
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366149 Test Start : 02/08/2016 @ 14:06
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:53
Location : First Floor-Girls PE Off Received: 02/17/2016 @ 15:18
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 09:57
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366153 Test Start : 02/08/2016 @ 14:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:55
Location : First Floor-Boy PE OFF Received: 02/17/2016 @ 15:18
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 09:22
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366156 Test Start : 02/08/2016 @ 13:26
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:20
Location : First Floor-96 Received: 02/17/2016 @ 15:17
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 09:22
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2366158 Test Start : 02/08/2016 @ 14:04
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:50
Location : First Floor-201 Received: 02/17/2016 @ 15:18
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 11:44
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2366165 Test Start : 02/08/2016 @ 13:50
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:37
Location : First Floor-121 Pract Received: 02/17/2016 @ 15:17
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 10:20
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2366167 Test Start : 02/08/2016 @ 13:53
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:39
Location : First Floor-Stage Received: 02/17/2016 @ 15:17
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 12:18
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366169 Test Start : 02/08/2016 @ 13:39
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:28
Location : First Floor-109 Received: 02/17/2016 @ 15:17
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 11:28
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366171 Test Start : 02/08/2016 @ 14:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:59
Location : First Floor-Fac Rm Received: 02/17/2016 @ 15:18
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 12:18
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2366175 Test Start : 02/08/2016 @ 14:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:59
Location : First Floor-2 Received: 02/17/2016 @ 15:18
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 12:00
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2366181 Test Start : 02/08/2016 @ 13:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:15
Location : First Floor-Main Off Received: 02/17/2016 @ 15:17
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 09:22
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366188 Test Start : 02/08/2016 @ 14:08
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:54
Location : First Floor-Gym Received: 02/17/2016 @ 15:18
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 10:20
Upside down.

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366193 Test Start : 02/08/2016 @ 14:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:55
Location : First Floor-Boys PE Off Received: 02/17/2016 @ 15:18
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 09:40
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366196 Test Start : 02/08/2016 @ 13:54
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:39
Location : First Floor-Cafe Received: 02/17/2016 @ 15:17
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 12:52
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2366203 Test Start : 02/08/2016 @ 13:27
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:21
Location : First Floor-107 Received: 02/17/2016 @ 15:17
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 12:52
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2366266 Test Start : 02/08/2016 @ 14:02
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:44
Location : First Floor-206 Received: 02/17/2016 @ 15:18
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 12:18



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# :	2366270	Test Start :	02/08/2016 @ 13:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/11/2016 @ 14:22
Location :	First Floor-121	Received:	02/17/2016 @ 15:17
Radon Level :	0.3 pCi/L	Analyzed:	02/18/2016 @ 10:20
Error for Measurement is:	\pm 0.6 pCi/L		

Canister ID# :	2366272	Test Start :	02/08/2016 @ 13:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/11/2016 @ 14:36
Location :	First Floor-113A	Received:	02/17/2016 @ 15:17
Radon Level :	0.5 pCi/L	Analyzed:	02/18/2016 @ 11:44
Error for Measurement is:	\pm 0.6 pCi/L		

Canister ID# :	2366273	Test Start :	02/08/2016 @ 13:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/11/2016 @ 14:33
Location :	First Floor-116	Received:	02/17/2016 @ 15:17
Radon Level :	0.2 pCi/L	Analyzed:	02/18/2016 @ 11:28
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	2366274	Test Start :	02/08/2016 @ 13:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/11/2016 @ 14:35
Location :	First Floor-119	Received:	02/17/2016 @ 15:17
Radon Level :	1.4 pCi/L	Analyzed:	02/18/2016 @ 12:53
Error for Measurement is:	\pm 0.6 pCi/L		

Canister ID# :	2366276	Test Start :	02/08/2016 @ 13:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/11/2016 @ 14:19
Location :	First Floor-97 Health	Received:	02/17/2016 @ 15:17
Radon Level :	0.7 pCi/L	Analyzed:	02/18/2016 @ 11:28
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	2366459	Test Start :	02/08/2016 @ 14:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/11/2016 @ 14:51
Location :	First Floor-205	Received:	02/17/2016 @ 15:18
Radon Level :	1.0 pCi/L	Analyzed:	02/18/2016 @ 10:20
Error for Measurement is:	\pm 0.7 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2366461 Test Start : 02/08/2016 @ 13:42
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:33
Location : First Floor-116 Received: 02/17/2016 @ 15:17
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 11:44
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366462 Test Start : 02/08/2016 @ 13:29
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:23
Location : First Floor-122 Received: 02/17/2016 @ 15:17
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 10:20
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366464 Test Start : 02/08/2016 @ 13:28
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:23
Location : First Floor-121/122 Received: 02/17/2016 @ 15:17
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 09:57
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366468 Test Start : 02/08/2016 @ 13:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:29
Location : First Floor-112 Received: 02/17/2016 @ 15:17
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:00
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2367042 Test Start : 02/08/2016 @ 14:01
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:44
Location : First Floor-207 Received: 02/17/2016 @ 15:18
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 09:40
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2367050 Test Start : 02/08/2016 @ 13:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:32
Location : First Floor-115 Received: 02/17/2016 @ 15:17
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 12:00
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2367062 Test Start : 02/08/2016 @ 13:31
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:24
Location : First Floor-108 Received: 02/17/2016 @ 15:17
Radon Level : 2.0 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2367064 Test Start : 02/08/2016 @ 13:43
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:34
Location : First Floor-118 Received: 02/17/2016 @ 15:17
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 11:44
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2367259 Test Start : 02/08/2016 @ 14:03
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:45
Location : First Floor-204 Received: 02/17/2016 @ 15:18
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 11:44
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2367261 Test Start : 02/08/2016 @ 13:26
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:21
Location : First Floor-105 Received: 02/17/2016 @ 15:17
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 12:00
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2367265 Test Start : 02/08/2016 @ 13:34
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:26
Location : First Floor-103 Received: 02/17/2016 @ 15:17
Radon Level : 1.8 pCi/L Analyzed: 02/18/2016 @ 14:31
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2367269 Test Start : 02/08/2016 @ 13:40
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:28
Location : First Floor-110 Received: 02/17/2016 @ 15:17
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 09:57
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2367270 Test Start : 02/08/2016 @ 13:19
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:15
Location : First Floor-VP Off Entry Received: 02/17/2016 @ 15:17
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 09:40
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2374656 Test Start : 02/08/2016 @ 14:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:59
Location : First Floor-Fac Rm Received: 02/17/2016 @ 15:18
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 11:44
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2374924 Test Start : 02/08/2016 @ 14:05
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:50
Location : First Floor-203 Received: 02/17/2016 @ 15:18
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 11:28
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2396299 Test Start : 02/08/2016 @ 14:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:59
Location : First Floor-BL Received: 02/17/2016 @ 15:18
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:00
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396617 Test Start : 02/08/2016 @ 14:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:59
Location : First Floor-BL Received: 02/17/2016 @ 15:18
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:18
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2396741 Test Start : 02/08/2016 @ 14:07
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:53
Location : First Floor-Girls Locker Rm Received: 02/17/2016 @ 15:18
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 10:20
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396814 Test Start : 02/08/2016 @ 14:17
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:58
Location : First Floor-Lib Received: 02/17/2016 @ 15:18
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 11:28
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396850 Test Start : 02/08/2016 @ 14:11
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:56
Location : First Floor-211 Received: 02/17/2016 @ 15:18
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396854 Test Start : 02/08/2016 @ 14:13
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:57
Location : First Floor-208 Received: 02/17/2016 @ 15:18
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 12:00
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2396863 Test Start : 02/08/2016 @ 14:17
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:58
Location : First Floor-Lib Received: 02/17/2016 @ 15:18
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 12:00
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2396873 Test Start : 02/08/2016 @ 13:46
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:36
Location : First Floor-113B Received: 02/17/2016 @ 15:17
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2398831 Test Start : 02/08/2016 @ 14:16
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:58
Location : First Floor-Lib Off Received: 02/17/2016 @ 15:18
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:18
Error for Measurement is: ± 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2403735 Test Start : 02/08/2016 @ 13:52
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:38
Location : First Floor-Music 121 Received: 02/17/2016 @ 15:17
Radon Level : 1.1 pCi/L Analyzed: 02/18/2016 @ 09:57
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2404124 Test Start : 02/08/2016 @ 14:11
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:56
Location : First Floor-210 Received: 02/17/2016 @ 15:18
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 10:20
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2404390 Test Start : 02/08/2016 @ 14:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:59
Location : First Floor-BL Received: 02/17/2016 @ 15:18
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 11:28
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2404397 Test Start : 02/08/2016 @ 14:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/11/2016 @ 14:59
Location : First Floor-BL Received: 02/17/2016 @ 15:18
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:18
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central School
119 South Ave
Webster, NY 14580-

Client: Plank North Elementary
Test Location: 705 Plank Road
Webster, NY 14580-
Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201