

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2349386 Test Start : 02/09/2016 @ 13:37
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:29
Location : W13 Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 16:44
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2349397 Test Start : 02/09/2016 @ 13:34
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:27
Location : First Floor-W10 Received: 02/17/2016 @ 10:59
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 16:44
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2349399 Test Start : 02/09/2016 @ 13:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:32
Location : East Caf Received: 02/17/2016 @ 10:59
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2350064 Test Start : 02/09/2016 @ 12:52
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:53
Location : First Floor-128 Stor Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2356589 Test Start : 02/09/2016 @ 13:33
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:27
Location : First Floor-Sec Off Received: 02/17/2016 @ 10:59
Radon Level : 1.3 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2360403 Test Start : 02/09/2016 @ 13:16
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:15
Location : First Floor-Lib Off Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 16:44
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2360410 Test Start : 02/09/2016 @ 13:30
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:26
Location : First Floor-Boys PE Off Received: 02/17/2016 @ 10:59
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2360414 Test Start : 02/09/2016 @ 13:57
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:58
Location : First Floor-138 Received: 02/17/2016 @ 10:58
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2362915 Test Start : 02/09/2016 @ 13:55
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:52
Location : Second Floor-238 Received: 02/17/2016 @ 10:59
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 16:45
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366162 Test Start : 02/09/2016 @ 14:08
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:59
Location : Third Floor-Con Rm B Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2366192 Test Start : 02/09/2016 @ 13:17
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:15
Location : First Floor-Lib Received: 02/17/2016 @ 10:58
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366265 Test Start : 02/09/2016 @ 14:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 15:00
Location : BL Received: 02/17/2016 @ 10:59
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2366269 Test Start : 02/09/2016 @ 13:52
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:48
Location : Second Floor-225 Received: 02/17/2016 @ 10:59
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366457 Test Start : 02/09/2016 @ 13:04
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:10
Location : First Floor-136 Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2366465 Test Start : 02/09/2016 @ 13:30
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:25
Location : First Floor-Boys PE Off Received: 02/17/2016 @ 10:59
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366469 Test Start : 02/09/2016 @ 12:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:49
Location : 123 Received: 02/17/2016 @ 10:58
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2367262 Test Start : 02/09/2016 @ 13:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:32
Location : East Caf Received: 02/17/2016 @ 10:59
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2367272 Test Start : 02/09/2016 @ 13:01
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:02
Location : First Floor-147 Received: 02/17/2016 @ 10:58
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2367618 Test Start : 02/09/2016 @ 12:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:50
Location : 125 Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 17:21
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2372009 Test Start : 02/09/2016 @ 13:51
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:46
Location : Second Floor-218 Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 16:44
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2396304 Test Start : 02/09/2016 @ 12:49
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:51
Location : First Floor-129 Stor Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 16:44
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2396305 Test Start : 02/09/2016 @ 14:06
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:56
Location : Third Floor-305 Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396308 Test Start : 02/09/2016 @ 14:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 15:00
Location : BL Received: 02/17/2016 @ 10:59
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396311 Test Start : 02/09/2016 @ 12:39
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:42
Location : First Floor-Harbeck Off Received: 02/17/2016 @ 10:58
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 14:32
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396312 Test Start : 02/09/2016 @ 13:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:24
Location : First Floor-Main Gym Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2396313 Test Start : 02/09/2016 @ 13:02
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:04
Location : First Floor-146 Received: 02/17/2016 @ 10:58
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396314 Test Start : 02/09/2016 @ 13:00
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:01
Location : First Floor-145 Received: 02/17/2016 @ 10:58
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 10:20
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396319 Test Start : 02/09/2016 @ 12:49
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:51
Location : First Floor-129 Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2396320 Test Start : 02/09/2016 @ 12:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:44
Location : First Floor-Health/Hearing Rm Received: 02/17/2016 @ 10:58
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396321 Test Start : 02/09/2016 @ 13:02
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:08
Location : First Floor-144 Off Received: 02/17/2016 @ 10:58
Radon Level : 1.1 pCi/L Analyzed: 02/18/2016 @ 16:45
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396323 Test Start : 02/09/2016 @ 13:11
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:12
Location : First Floor-124 Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396326 Test Start : 02/09/2016 @ 12:45
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:48
Location : 119/121 Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2396329 Test Start : 02/09/2016 @ 12:37
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:41
Location : First Floor-Main Off Recep Received: 02/17/2016 @ 10:58
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396337 Test Start : 02/09/2016 @ 12:37
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:40
Location : First Floor-109 Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396338 Test Start : 02/09/2016 @ 14:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 15:00
Location : BL Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2396340 Test Start : 02/09/2016 @ 13:21
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:21
Location : First Floor-108 Received: 02/17/2016 @ 10:59
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396341
Canister Type : Charcoal Canister 3 inch
Location : First Floor-Rear Gym
Radon Level : 0.2 pCi/L
Error for Measurement is: \pm 0.5 pCi/L
Test Start : 02/09/2016 @ 13:24
Test Stop : 02/12/2016 @ 14:24
Received: 02/17/2016 @ 10:59
Analyzed: 02/18/2016 @ 15:12

Canister ID# : 2396346
Canister Type : Charcoal Canister 3 inch
Location : 121
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.6 pCi/L
Test Start : 02/09/2016 @ 12:46
Test Stop : 02/12/2016 @ 13:49
Received: 02/17/2016 @ 10:58
Analyzed: 02/18/2016 @ 15:27

Canister ID# : 2396351
Canister Type : Charcoal Canister 3 inch
Location : First Floor-128
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/09/2016 @ 12:51
Test Stop : 02/12/2016 @ 13:52
Received: 02/17/2016 @ 10:58
Analyzed: 02/18/2016 @ 16:14

Canister ID# : 2396352
Canister Type : Charcoal Canister 3 inch
Location : First Floor-Stephan Off
Radon Level : 0.4 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/09/2016 @ 12:38
Test Stop : 02/12/2016 @ 13:42
Received: 02/17/2016 @ 10:58
Analyzed: 02/18/2016 @ 15:59

Canister ID# : 2396356
Canister Type : Charcoal Canister 3 inch
Location : First Floor-Mungo Off
Radon Level : 0.2 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/09/2016 @ 12:40
Test Stop : 02/12/2016 @ 13:44
Received: 02/17/2016 @ 10:58
Analyzed: 02/18/2016 @ 14:32

Canister ID# : 2396358
Canister Type : Charcoal Canister 3 inch
Location : First Floor-120
Radon Level : 0.2 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/09/2016 @ 13:12
Test Stop : 02/12/2016 @ 14:12
Received: 02/17/2016 @ 10:58
Analyzed: 02/18/2016 @ 12:53



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396359 Test Start : 02/09/2016 @ 14:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 15:00
Location : BL Received: 02/17/2016 @ 10:59
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 15:27
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396361 Test Start : 02/09/2016 @ 13:58
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:58
Location : First Floor-138 Greenhouse Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396362 Test Start : 02/09/2016 @ 13:49
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:46
Location : Second Floor-211 Received: 02/17/2016 @ 10:59
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396363 Test Start : 02/09/2016 @ 13:11
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:12
Location : First Floor-122 Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396367 Test Start : 02/09/2016 @ 13:26
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:25
Location : First Floor-Main Gym Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:52
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2396374 Test Start : 02/09/2016 @ 13:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:23
Location : First Floor-Rear Gym Received: 02/17/2016 @ 10:59
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396584 Test Start : 02/09/2016 @ 13:02
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:02
Location : First Floor-148 Received: 02/17/2016 @ 10:58
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396589 Test Start : 02/09/2016 @ 12:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:44
Location : First Floor-Health Off Received: 02/17/2016 @ 10:58
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396593 Test Start : 02/09/2016 @ 13:22
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:22
Location : Girls PE Off Coach Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 09:22
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2396596 Test Start : 02/09/2016 @ 12:53
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:54
Location : First Floor-130 Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2396604 Test Start : 02/09/2016 @ 13:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:16
Location : First Floor-Lib Off /Stor Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 17:21
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2396613 Test Start : 02/09/2016 @ 13:39
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:31
Location : West Caf Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: ± 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396614 Test Start : 02/09/2016 @ 12:59
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:00
Location : First Floor-141 Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396616 Test Start : 02/09/2016 @ 13:20
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:17
Location : First Floor-Cust Off Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2398439 Test Start : 02/09/2016 @ 13:00
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:01
Location : First Floor-145 Received: 02/17/2016 @ 10:58
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2398442 Test Start : 02/09/2016 @ 13:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:11
Location : First Floor-126 Received: 02/17/2016 @ 10:58
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2401510 Test Start : 02/09/2016 @ 13:48
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:45
Location : Second Floor-203 Received: 02/17/2016 @ 10:59
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2401514 Test Start : 02/09/2016 @ 12:39
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:43
Location : First Floor-Mylott Off Received: 02/17/2016 @ 10:58
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2401518 Test Start : 02/09/2016 @ 13:37
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:28
Location : First Floor-W15 Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 17:21
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2401522 Test Start : 02/09/2016 @ 13:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:11
Location : First Floor-126 Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2401523 Test Start : 02/09/2016 @ 12:54
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:55
Location : First Floor-134 Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 16:44
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2401532 Test Start : 02/09/2016 @ 12:50
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:52
Location : First Floor-131 Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2401533 Test Start : 02/09/2016 @ 12:37
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:40
Location : First Floor-Princ Off Received: 02/17/2016 @ 10:58
Radon Level : 0.2 pCi/L Analyzed: 02/17/2016 @ 17:40
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2401537 Test Start : 02/09/2016 @ 13:06
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:10
Location : First Floor-136 Stor Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 17:21
Error for Measurement is: ± 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2401538 Test Start : 02/09/2016 @ 12:44
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:45
Location : First Floor-117 Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:53
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2401542 Test Start : 02/09/2016 @ 13:00
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:00
Location : First Floor-143 Received: 02/17/2016 @ 10:58
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2402717 Test Start : 02/09/2016 @ 13:20
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:20
Location : First Floor-110 Copy Received: 02/17/2016 @ 10:58
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 17:21
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2402726 Test Start : 02/09/2016 @ 12:51
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:52
Location : First Floor-128 Received: 02/17/2016 @ 10:58
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2403673 Test Start : 02/09/2016 @ 13:22
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:22
Location : Girls PE Off Received: 02/17/2016 @ 10:59
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 14:32
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2403684 Test Start : 02/09/2016 @ 13:04
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:09
Location : First Floor-142 Received: 02/17/2016 @ 10:58
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2403695 Test Start : 02/09/2016 @ 12:44
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:45
Location : First Floor-117 Received: 02/17/2016 @ 10:58
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2403740 Test Start : 02/09/2016 @ 12:55
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:58
Location : First Floor-140 Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:53
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2403742 Test Start : 02/09/2016 @ 13:56
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:52
Location : Second Floor-245 Received: 02/17/2016 @ 10:59
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2403748 Test Start : 02/09/2016 @ 13:03
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:08
Location : First Floor-144 Main Received: 02/17/2016 @ 10:58
Radon Level : 1.1 pCi/L Analyzed: 02/18/2016 @ 16:44
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2403751 Test Start : 02/09/2016 @ 13:38
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:29
Location : W11 Received: 02/17/2016 @ 10:59
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2403780 Test Start : 02/09/2016 @ 14:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 15:00
Location : Third Floor-323 Received: 02/17/2016 @ 10:59
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 16:44
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2403781 Test Start : 02/09/2016 @ 14:04
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:55
Location : Third Floor-301 Received: 02/17/2016 @ 10:59
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2403790 Test Start : 02/09/2016 @ 13:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:24
Location : First Floor-Main Gym Received: 02/17/2016 @ 10:59
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2403799 Test Start : 02/09/2016 @ 12:53
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:55
Location : First Floor-132 Received: 02/17/2016 @ 10:58
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2403801 Test Start : 02/09/2016 @ 12:48
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:50
Location : 127 Received: 02/17/2016 @ 10:58
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2403841 Test Start : 02/09/2016 @ 13:20
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:20
Location : First Floor-110 Copy Received: 02/17/2016 @ 10:58
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2403849 Test Start : 02/09/2016 @ 13:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:28
Location : First Floor-W12 Received: 02/17/2016 @ 10:59
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 14:31
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2404330 Test Start : 02/09/2016 @ 12:45
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:48
Location : 119 Received: 02/17/2016 @ 10:58
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404340 Test Start : 02/09/2016 @ 13:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:45
Location : Second Floor-W23 Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404359 Test Start : 02/09/2016 @ 13:40
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:31
Location : Kitchen Office Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 14:32
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2404375 Test Start : 02/09/2016 @ 12:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 13:44
Location : First Floor-Health Recept Received: 02/17/2016 @ 10:58
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404403 Test Start : 02/09/2016 @ 13:12
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:12
Location : First Floor-120 Off Received: 02/17/2016 @ 10:58
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404406 Test Start : 02/09/2016 @ 13:36
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:28
Location : First Floor-W17 Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: ± 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2404415 Test Start : 02/09/2016 @ 13:03
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:08
Location : First Floor-144 Off Received: 02/17/2016 @ 10:58
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2404422 Test Start : 02/09/2016 @ 13:28
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:25
Location : First Floor-Boys Coach Off Received: 02/17/2016 @ 10:59
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 15:27
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2404435 Test Start : 02/09/2016 @ 13:54
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:49
Location : Second Floor-230 Received: 02/17/2016 @ 10:59
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2404439 Test Start : 02/09/2016 @ 13:17
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 14:16
Location : First Floor-Lib Received: 02/17/2016 @ 10:58
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 12:53
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Spry Middle School
Test Location: 119 South Avenue
Webster, NY 14580-
Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

*Andreas C. George*

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201