

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
Webster Central School District
119 South Ave
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396301 Test Start : 01/19/2016 @ 12:55
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:29
Location : 11 S. Back Received: 01/27/2016 @ 15:01
Radon Level : 0.7 pCi/L Analyzed: 01/28/2016 @ 14:51
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396862 Test Start : 01/19/2016 @ 13:36
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:48
Location : Gym Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 14:51
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396866 Test Start : 01/19/2016 @ 13:07
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:33
Location : Nurses Received: 01/27/2016 @ 15:02
Radon Level : 0.4 pCi/L Analyzed: 01/27/2016 @ 16:51
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396876 Test Start : 01/19/2016 @ 13:30
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:45
Location : Bodensteiner Received: 01/27/2016 @ 15:02
Radon Level : 0.2 pCi/L Analyzed: 01/27/2016 @ 16:51
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396878 Test Start : 01/19/2016 @ 14:19
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:08
Location : BL Received: 01/27/2016 @ 15:02
Radon Level : 0.3 pCi/L Analyzed: 01/28/2016 @ 14:16
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2396879 Test Start : 01/19/2016 @ 13:16
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:37
Location : 122 Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 15:07
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
119 South Ave
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396882 Test Start : 01/19/2016 @ 13:48
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:53
Location : Library Received: 01/27/2016 @ 15:02
Radon Level : 0.5 pCi/L Analyzed: 01/28/2016 @ 15:21
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396883 Test Start : 01/19/2016 @ 13:38
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:48
Location : Gym Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 15:07
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396888 Test Start : 01/19/2016 @ 14:00
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:59
Location : Riston Received: 01/27/2016 @ 15:02
Radon Level : 0.5 pCi/L Analyzed: 01/28/2016 @ 14:51
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396890 Test Start : 01/19/2016 @ 14:00
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:58
Location : Cafe Received: 01/27/2016 @ 15:02
Radon Level : 1.0 pCi/L Analyzed: 01/28/2016 @ 15:57
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2396891 Test Start : 01/19/2016 @ 12:54
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:27
Location : 101-102 Store Rm Received: 01/27/2016 @ 15:02
Radon Level : 0.9 pCi/L Analyzed: 01/28/2016 @ 16:15
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396894 Test Start : 01/19/2016 @ 13:13
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:36
Location : 118 Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 14:51
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
119 South Ave
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396895 Test Start : 01/19/2016 @ 13:58
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:58
Location : Cafe Received: 01/27/2016 @ 15:02
Radon Level : 0.4 pCi/L Analyzed: 01/28/2016 @ 15:22
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396896 Test Start : 01/19/2016 @ 14:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:00
Location : Kitchen Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/27/2016 @ 16:51
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396899 Test Start : 01/19/2016 @ 12:59
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:30
Location : 105 Received: 01/27/2016 @ 15:02
Radon Level : 0.3 pCi/L Analyzed: 01/28/2016 @ 16:30
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396903 Test Start : 01/19/2016 @ 12:53
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:27
Location : 101 Received: 01/27/2016 @ 15:02
Radon Level : 0.2 pCi/L Analyzed: 01/28/2016 @ 16:15
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396905 Test Start : 01/19/2016 @ 14:19
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:08
Location : BL Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 16:29
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2396908 Test Start : 01/19/2016 @ 13:58
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:58
Location : Stage Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 15:07
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
119 South Ave
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396909 Test Start : 01/19/2016 @ 13:31
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:45
Location : Main Off Break Rm Received: 01/27/2016 @ 15:02
Radon Level : 0.3 pCi/L Analyzed: 01/28/2016 @ 16:15
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396913 Test Start : 01/19/2016 @ 13:39
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:51
Location : Boys Locker Rm Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/27/2016 @ 16:50
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396917 Test Start : 01/19/2016 @ 14:17
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:07
Location : 210 Received: 01/27/2016 @ 15:02
Radon Level : 1.7 pCi/L Analyzed: 01/28/2016 @ 16:30
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396926 Test Start : 01/19/2016 @ 14:19
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:08
Location : BL Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 16:29
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396929 Test Start : 01/19/2016 @ 13:39
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:50
Location : Gym Store Rm Received: 01/27/2016 @ 15:02
Radon Level : 0.7 pCi/L Analyzed: 01/28/2016 @ 15:42
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396931 Test Start : 01/19/2016 @ 13:15
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:36
Location : 120 Received: 01/27/2016 @ 15:02
Radon Level : 0.2 pCi/L Analyzed: 01/28/2016 @ 15:07
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
119 South Ave
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396932 Test Start : 01/19/2016 @ 13:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:47
Location : Girls Phys Ed Received: 01/27/2016 @ 15:02
Radon Level : 0.7 pCi/L Analyzed: 01/28/2016 @ 14:16
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2396935 Test Start : 01/19/2016 @ 13:04
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:32
Location : 107 Received: 01/27/2016 @ 15:02
Radon Level : 0.3 pCi/L Analyzed: 01/28/2016 @ 16:29
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2396938 Test Start : 01/19/2016 @ 14:16
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:07
Location : Bennet Received: 01/27/2016 @ 15:02
Radon Level : 1.3 pCi/L Analyzed: 01/28/2016 @ 16:30
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396942 Test Start : 01/19/2016 @ 12:59
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:29
Location : 104 Received: 01/27/2016 @ 15:01
Radon Level : 0.2 pCi/L Analyzed: 01/28/2016 @ 15:41
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396943 Test Start : 01/19/2016 @ 13:21
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:41
Location : 5-15 Received: 01/27/2016 @ 15:02
Radon Level : 0.4 pCi/L Analyzed: 01/28/2016 @ 16:30
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396944 Test Start : 01/19/2016 @ 13:31
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:45
Location : Conf Rm Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 16:15
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
Webster Central School District
119 South Avenue
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396945 Test Start : 01/19/2016 @ 14:18
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:08
Location : 211 Received: 01/27/2016 @ 15:02
Radon Level : 1.3 pCi/L Analyzed: 01/28/2016 @ 15:42
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396947 Test Start : 01/19/2016 @ 14:19
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:08
Location : 214 Received: 01/27/2016 @ 15:02
Radon Level : 0.7 pCi/L Analyzed: 01/27/2016 @ 16:50
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396953 Test Start : 01/19/2016 @ 13:06
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:32
Location : 109 Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 16:14
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2396956 Test Start : 01/19/2016 @ 13:16
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:37
Location : 122 Received: 01/27/2016 @ 15:02
Radon Level : 0.3 pCi/L Analyzed: 01/28/2016 @ 14:51
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396960 Test Start : 01/19/2016 @ 14:01
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:57
Location : Custodian Received: 01/27/2016 @ 15:02
Radon Level : 0.6 pCi/L Analyzed: 01/28/2016 @ 13:56
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396967 Test Start : 01/19/2016 @ 13:41
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:52
Location : Girls Locker Rm Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 15:21
Error for Measurement is: ± 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
119 South Ave
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2398396 Test Start : 01/19/2016 @ 13:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:35
Location : 112 Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 14:36
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2398398 Test Start : 01/19/2016 @ 14:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:05
Location : Music Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/27/2016 @ 16:51
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2398400 Test Start : 01/19/2016 @ 14:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:05
Location : Music Received: 01/27/2016 @ 15:02
Radon Level : 0.1 pCi/L Analyzed: 01/28/2016 @ 15:07

Average of Side by Side Canisters 0.1 pCi/L
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2398405 Test Start : 01/19/2016 @ 12:59
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:30
Location : 103 Received: 01/27/2016 @ 15:02
Radon Level : 0.3 pCi/L Analyzed: 01/28/2016 @ 15:07
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2398406 Test Start : 01/19/2016 @ 14:08
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:04
Location : 201 Received: 01/27/2016 @ 15:02
Radon Level : 0.2 pCi/L Analyzed: 01/28/2016 @ 15:22
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2398420 Test Start : 01/19/2016 @ 13:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:34
Location : 111 Received: 01/27/2016 @ 15:02
Radon Level : 0.4 pCi/L Analyzed: 01/28/2016 @ 15:41
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
119 South Ave
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2398469 Test Start : 01/19/2016 @ 13:01
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:31
Location : 108 Received: 01/27/2016 @ 15:02
Radon Level : 0.5 pCi/L Analyzed: 01/28/2016 @ 16:15
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2398482 Test Start : 01/19/2016 @ 14:03
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:02
Location : Art Rm Received: 01/27/2016 @ 15:02
Radon Level : 0.7 pCi/L Analyzed: 01/28/2016 @ 15:07
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2401525 Test Start : 01/19/2016 @ 13:30
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:45
Location : Main Off Break Rm Received: 01/27/2016 @ 15:02
Radon Level : 0.5 pCi/L Analyzed: 01/28/2016 @ 15:07
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2401536 Test Start : 01/19/2016 @ 13:45
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:52
Location : 115 Received: 01/27/2016 @ 15:02
Radon Level : 0.8 pCi/L Analyzed: 01/28/2016 @ 16:15
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2404217 Test Start : 01/19/2016 @ 13:40
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:51
Location : Coaches Off Received: 01/27/2016 @ 15:02
Radon Level : 0.2 pCi/L Analyzed: 01/28/2016 @ 14:18
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2404222 Test Start : 01/19/2016 @ 14:18
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:08
Location : 212 Received: 01/27/2016 @ 15:02
Radon Level : 0.9 pCi/L Analyzed: 01/28/2016 @ 15:07
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
Webster Central School District
119 South Ave
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2404276 Test Start : 01/19/2016 @ 12:55
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:28
Location : 11.S Front Received: 01/27/2016 @ 15:02
Radon Level : 0.5 pCi/L Analyzed: 01/28/2016 @ 14:51
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2404288 Test Start : 01/19/2016 @ 13:42
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:52
Location : 115-USchold Received: 01/27/2016 @ 15:02
Radon Level : 0.2 pCi/L Analyzed: 01/27/2016 @ 16:50
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2404291 Test Start : 01/19/2016 @ 13:45
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:52
Location : 115 Received: 01/27/2016 @ 15:02
Radon Level : 0.6 pCi/L Analyzed: 01/27/2016 @ 16:51
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2404300 Test Start : 01/19/2016 @ 13:12
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:35
Location : 116 Received: 01/27/2016 @ 15:02
Radon Level : 0.3 pCi/L Analyzed: 01/28/2016 @ 16:29
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404301 Test Start : 01/19/2016 @ 13:23
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 14:43
Location : Mrs Eaton Received: 01/27/2016 @ 15:02
Radon Level : 0.2 pCi/L Analyzed: 01/28/2016 @ 16:30
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2404311 Test Start : 01/19/2016 @ 14:13
Canister Type : Charcoal Canister 3 inch Test Stop : 01/22/2016 @ 15:06
Location : 200-B Received: 01/27/2016 @ 15:02
Radon Level : 0.2 pCi/L Analyzed: 01/27/2016 @ 16:51
Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/27/2016

Blaine Cunningham
Webster Central School District
119 South Avenue
Webster, NY 14580-

Client: State Road Elementary School
Test Location: 1401 State Road
Webster, NY 14580-

Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

*Andreas C. George*

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201