

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2398337
Canister Type : Charcoal Canister 3 inch
Location : First FI 42
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.7 pCi/L

Test Start : 02/22/2016 @ 10:21
Test Stop : 02/25/2016 @ 13:04
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 14:23

Canister ID# : 2398347
Canister Type : Charcoal Canister 3 inch
Location : First FI 191
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 11:05
Test Stop : 02/25/2016 @ 13:24
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:09

Canister ID# : 2398354
Canister Type : Charcoal Canister 3 inch
Location : First FI 22
Radon Level : **0.9 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 09:56
Test Stop : 02/25/2016 @ 12:43
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 14:54

Canister ID# : 2398358
Canister Type : Charcoal Canister 3 inch
Location : First FI 48
Radon Level : **0.6 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:22
Test Stop : 02/25/2016 @ 13:49
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:04

Canister ID# : 2398360
Canister Type : Charcoal Canister 3 inch
Location : First FI Library
Radon Level : **0.6 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 11:17
Test Stop : 02/25/2016 @ 13:46
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:18

Canister ID# : 2398361
Canister Type : Charcoal Canister 3 inch
Location : First FI 38
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 10:17
Test Stop : 02/25/2016 @ 13:02
Received: 03/03/2016 @ 09:54
Analyzed: 03/04/2016 @ 10:24

Canister ID# : 2398362
Canister Type : Charcoal Canister 3 inch
Location : First FI 37
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 10:19
Test Stop : 02/25/2016 @ 13:03
Received: 03/03/2016 @ 09:54
Analyzed: 03/04/2016 @ 10:43



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2398363 Test Start : 02/22/2016 @ 11:06
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:25
Location : First FI 187 Received: 03/03/2016 @ 09:54
Radon Level : **0.6 pCi/L** Analyzed: 03/03/2016 @ 16:30
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2398377 Test Start : 02/22/2016 @ 09:45
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:40
Location : First FI Main Office Recep Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:34
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2398379 Test Start : 02/22/2016 @ 10:15
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:00
Location : First FI 36 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/04/2016 @ 10:43
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2398401 Test Start : 02/22/2016 @ 10:33
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:09
Location : First FI 45E Open Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:53
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2398411 Test Start : 02/22/2016 @ 10:19
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:03
Location : First FI 40 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 15:09
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2398412 Test Start : 02/22/2016 @ 10:28
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:08
Location : First FI Counseling Recep Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 15:09
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2398413 Test Start : 02/22/2016 @ 12:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:27
Location : First FI Wrestling Rm Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:23
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2398415 Test Start : 02/22/2016 @ 10:17
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:02
Location : First FI 38 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:04



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2398423
Canister Type : Charcoal Canister 3 inch
Location : First FI 39
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 10:20
Test Stop : 02/25/2016 @ 13:03
Received: 03/03/2016 @ 09:54
Analyzed: 03/04/2016 @ 10:24

Canister ID# : 2398424
Canister Type : Charcoal Canister 3 inch
Location : First FI Pool
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 12:40
Test Stop : 02/25/2016 @ 14:36
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:53

Canister ID# : 2398426
Canister Type : Charcoal Canister 3 inch
Location : First FI Field House
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 12:24
Test Stop : 02/25/2016 @ 14:27
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:40

Canister ID# : 2398465
Canister Type : Charcoal Canister 3 inch
Location : First FI Blue House Office
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 10:40
Test Stop : 02/25/2016 @ 13:12
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:34

Canister ID# : 2398467
Canister Type : Charcoal Canister 3 inch
Location : First FI 197
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:01
Test Stop : 02/25/2016 @ 13:22
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 16:10

Canister ID# : 2398475
Canister Type : Charcoal Canister 3 inch
Location : First FI 48
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 11:22
Test Stop : 02/25/2016 @ 13:49
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 16:30

Canister ID# : 2398476
Canister Type : Charcoal Canister 3 inch
Location : First FI 213
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 10:49
Test Stop : 02/25/2016 @ 13:17
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:34



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2398478 Test Start : 02/22/2016 @ 11:21
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:49
Location : First FI 46 Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 15:36
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2398481 Test Start : 02/22/2016 @ 10:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:07
Location : First FI Counseling Office Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 14:23
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2398483 Test Start : 02/22/2016 @ 10:22
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:05
Location : First FI 41 Received: 03/03/2016 @ 09:54
Radon Level : **0.5 pCi/L** Analyzed: 03/03/2016 @ 14:40
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2398485 Test Start : 02/22/2016 @ 12:03
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:20
Location : First FI 73W Received: 03/03/2016 @ 09:55
Radon Level : **0.7 pCi/L** Analyzed: 03/04/2016 @ 10:24
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2398826 Test Start : 02/22/2016 @ 11:31
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:59
Location : First FI 54 Received: 03/03/2016 @ 09:55
Radon Level : **0.8 pCi/L** Analyzed: 03/04/2016 @ 10:24
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2398829 Test Start : 02/22/2016 @ 11:13
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:44
Location : First FI Lib Copy Rm Received: 03/03/2016 @ 09:54
Radon Level : **0.4 pCi/L** Analyzed: 03/03/2016 @ 17:53
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2398832 Test Start : 02/22/2016 @ 11:42
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:04
Location : First FI 63 Received: 03/03/2016 @ 09:55
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 16:30
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2398833 Test Start : 02/22/2016 @ 10:08
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:53
Location : First FI 122 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/04/2016 @ 10:43



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2398835
Canister Type : Charcoal Canister 3 inch
Location : First FI 8
Radon Level : **0.2 pCi/L**

Test Start : 02/22/2016 @ 13:35
Test Stop : 02/25/2016 @ 15:07
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:04

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2398838
Canister Type : Charcoal Canister 3 inch
Location : First FI 96 Rear
Radon Level : **0.1 pCi/L**

Test Start : 02/22/2016 @ 12:50
Test Stop : 02/25/2016 @ 14:42
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:55

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2402241
Canister Type : Charcoal Canister 3 inch
Location : First FI Gold House Office
Radon Level : **0.9 pCi/L**

Test Start : 02/22/2016 @ 11:51
Test Stop : 02/25/2016 @ 14:09
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:54

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2402250
Canister Type : Charcoal Canister 3 inch
Location : First FI 94 Office
Radon Level : **0.4 pCi/L**

Test Start : 02/22/2016 @ 12:49
Test Stop : 02/25/2016 @ 14:41
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:53

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2402276
Canister Type : Charcoal Canister 3 inch
Location : First FI Gym
Radon Level : **0.1 pCi/L**

Test Start : 02/22/2016 @ 12:33
Test Stop : 02/25/2016 @ 14:33
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:55

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2402311
Canister Type : Charcoal Canister 3 inch
Location : First FI Gold House Office
Radon Level : **0.6 pCi/L**

Test Start : 02/22/2016 @ 11:49
Test Stop : 02/25/2016 @ 14:08
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:11

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2402356
Canister Type : Charcoal Canister 3 inch
Location : First FI 7 Open
Radon Level : **0.1 pCi/L**

Test Start : 02/22/2016 @ 13:29
Test Stop : 02/25/2016 @ 15:03
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:53

Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2402357 Test Start : 02/22/2016 @ 10:26
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:08
Location : First FI Counseling Office Received: 03/03/2016 @ 09:54
Radon Level : **0.3 pCi/L** Analyzed: 03/04/2016 @ 11:01
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2402359 Test Start : 02/22/2016 @ 12:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:40
Location : First FI 92 Received: 03/03/2016 @ 09:55
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 15:53
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402360 Test Start : 02/22/2016 @ 10:48
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:17
Location : First FI 215 Open Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:18
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2402363 Test Start : 02/22/2016 @ 13:07
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:54
Location : First FI Custodial Office Open Received: 03/03/2016 @ 09:55
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 16:48
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402365 Test Start : 02/22/2016 @ 10:46
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:15
Location : First FI 204 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:04
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402366 Test Start : 02/22/2016 @ 11:45
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:06
Location : First FI Gold House Office Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:40
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402368 Test Start : 02/22/2016 @ 13:34
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:06
Location : First FI 11 Received: 03/03/2016 @ 09:55
Radon Level : **0.5 pCi/L** Analyzed: 03/04/2016 @ 10:24
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2402369 Test Start : 02/22/2016 @ 13:33
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:05
Location : First FI 9 Received: 03/03/2016 @ 09:55
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 15:53



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2402370
Canister Type : Charcoal Canister 3 inch
Location : First FI 79S
Radon Level : **0.9 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 12:01
Test Stop : 02/25/2016 @ 14:18
Received: 03/03/2016 @ 09:55
Analyzed: 03/04/2016 @ 10:43

Canister ID# : 2402371
Canister Type : Charcoal Canister 3 inch
Location : First FI Gold House Office
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 11:50
Test Stop : 02/25/2016 @ 14:08
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:36

Canister ID# : 2402372
Canister Type : Charcoal Canister 3 inch
Location : First FI 51 Open
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:27
Test Stop : 02/25/2016 @ 13:55
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:53

Canister ID# : 2402375
Canister Type : Charcoal Canister 3 inch
Location : First FI 86
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 12:09
Test Stop : 02/25/2016 @ 14:24
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:10

Canister ID# : 2402376
Canister Type : Charcoal Canister 3 inch
Location : First FI Counseling Office
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 10:28
Test Stop : 02/25/2016 @ 13:08
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:53

Canister ID# : 2402377
Canister Type : Charcoal Canister 3 inch
Location : First FI 118
Radon Level : **0.6 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 13:12
Test Stop : 02/25/2016 @ 14:56
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:35

Canister ID# : 2402378
Canister Type : Charcoal Canister 3 inch
Location : First FI Cafeteria
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 12:55
Test Stop : 02/25/2016 @ 14:48
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:34



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2402379 Test Start : 02/22/2016 @ 13:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:55
Location : First FI 119 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:40
Error for Measurement is: ± 0.1 pCi/L

Canister ID# : 2402380 Test Start : 02/22/2016 @ 12:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:36
Location : First FI Pool Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 16:30
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402381 Test Start : 02/22/2016 @ 10:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:16
Location : First FI 208 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:40
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2402382 Test Start : 02/22/2016 @ 13:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:02
Location : First FI 3 Received: 03/03/2016 @ 09:55
Radon Level : **0.5 pCi/L** Analyzed: 03/04/2016 @ 10:43
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402385 Test Start : 02/22/2016 @ 13:26
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:02
Location : First FI 155 Open Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:04
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2402389 Test Start : 02/22/2016 @ 10:50
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:19
Location : First FI 209 Received: 03/03/2016 @ 09:54
Radon Level : **0.4 pCi/L** Analyzed: 03/03/2016 @ 17:04
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402390 Test Start : 02/22/2016 @ 12:00
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:16
Location : First FI 83 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:23
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402391 Test Start : 02/22/2016 @ 12:04
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:21
Location : First FI 76 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:23



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2402392
Canister Type : Charcoal Canister 3 inch
Location : First FI 110
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 13:18
Test Stop : 02/25/2016 @ 14:58
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:53

Canister ID# : 2402393
Canister Type : Charcoal Canister 3 inch
Location : First FI Book room
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 13:28
Test Stop : 02/25/2016 @ 15:02
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48

Canister ID# : 2402394
Canister Type : Charcoal Canister 3 inch
Location : First FI 119 Office
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 13:10
Test Stop : 02/25/2016 @ 14:55
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:10

Canister ID# : 2402396
Canister Type : Charcoal Canister 3 inch
Location : First FI 120
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.8 pCi/L

Test Start : 02/22/2016 @ 13:11
Test Stop : 02/25/2016 @ 14:56
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48

Canister ID# : 2402397
Canister Type : Charcoal Canister 3 inch
Location : First FI 196
Radon Level : **0.6 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 10:36
Test Stop : 02/25/2016 @ 13:11
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 14:23

Canister ID# : 2402398
Canister Type : Charcoal Canister 3 inch
Location : First FI 112 Storage
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 13:15
Test Stop : 02/25/2016 @ 14:58
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:36

Canister ID# : 2402399
Canister Type : Charcoal Canister 3 inch
Location : First FI Field House
Radon Level : **No Result**

Test Start : 02/22/2016 @ 12:23
Test Stop : 02/25/2016 @ 14:27
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:06

Radon concentration has been estimated due to missing stop time. The word "Gone" was noted on the data sheet also.

Error for Measurement is: \pm pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2402400 Test Start : 02/22/2016 @ 13:19
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:59
Location : First FI 108 Open Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/04/2016 @ 10:24
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2402401 Test Start : 02/22/2016 @ 11:04
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:23
Location : First FI 193 Open Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 15:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402404 Test Start : 02/22/2016 @ 12:48
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:41
Location : First FI 94 Received: 03/03/2016 @ 09:55
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 14:55
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402407 Test Start : 02/22/2016 @ 12:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:27
Location : First FI Field House Received: 03/03/2016 @ 09:55
Radon Level : **0.5 pCi/L** Analyzed: 03/03/2016 @ 16:30
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402408 Test Start : 02/22/2016 @ 11:01
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:21
Location : First FI 199 Received: 03/03/2016 @ 09:54
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 17:04
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2402409 Test Start : 02/22/2016 @ 11:51
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:09
Location : First FI Gold House Office Received: 03/03/2016 @ 09:55
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 14:55
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402414 Test Start : 02/22/2016 @ 12:33
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:33
Location : First FI Gym Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 16:30
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2402415 Test Start : 02/22/2016 @ 12:40
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:36
Location : First FI Pool Office Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:04



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2402416
Canister Type : Charcoal Canister 3 inch
Location : First FI 9
Radon Level : **0.5 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 13:33
Test Stop : 02/25/2016 @ 15:05
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:53

Canister ID# : 2402417
Canister Type : Charcoal Canister 3 inch
Location : First FI Counseling Conf Rm Op
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 10:24
Test Stop : 02/25/2016 @ 13:07
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:09

Canister ID# : 2402418
Canister Type : Charcoal Canister 3 inch
Location : First FI 1A
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.7 pCi/L

Test Start : 02/22/2016 @ 13:25
Test Stop : 02/25/2016 @ 15:01
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:35

Canister ID# : 2402419
Canister Type : Charcoal Canister 3 inch
Location : First FI 99 Athletic Trainer Open
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 12:51
Test Stop : 02/25/2016 @ 14:43
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48

Canister ID# : 2402420
Canister Type : Charcoal Canister 3 inch
Location : First FI Counseling Office
Radon Level : **0.5 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 10:27
Test Stop : 02/25/2016 @ 13:08
Received: 03/03/2016 @ 09:54
Analyzed: 03/04/2016 @ 10:24

Canister ID# : 2402421
Canister Type : Charcoal Canister 3 inch
Location : First FI 4 Open
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 13:31
Test Stop : 02/25/2016 @ 15:03
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:35

Canister ID# : 2402422
Canister Type : Charcoal Canister 3 inch
Location : First FI Custodial Office Open
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 02/22/2016 @ 13:06
Test Stop : 02/25/2016 @ 14:54
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2402756 Test Start : 02/22/2016 @ 12:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:27
Location : First FI Weight Rm Received: 03/03/2016 @ 09:55
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 15:35
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402759 Test Start : 02/22/2016 @ 12:02
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:19
Location : First FI 75 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:04
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402762 Test Start : 02/22/2016 @ 13:21
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:59
Location : First FI Nurse-Office Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:55
Error for Measurement is: ± 0.9 pCi/L

Canister ID# : 2402764 Test Start : 02/22/2016 @ 11:59
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:15
Location : First FI 85 Received: 03/03/2016 @ 09:55
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 14:23
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402765 Test Start : 02/22/2016 @ 10:37
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:11
Location : First FI 198 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:53
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2402766 Test Start : 02/22/2016 @ 10:43
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:13
Location : First FI Blue House Office Received: 03/03/2016 @ 09:54
Radon Level : **0.7 pCi/L** Analyzed: 03/04/2016 @ 10:24
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402767 Test Start : 02/22/2016 @ 13:03
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:50
Location : First FI Kitchen Office Received: 03/03/2016 @ 09:55
Radon Level : **0.3 pCi/L** Analyzed: 03/04/2016 @ 10:43
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402769 Test Start : 02/22/2016 @ 11:44
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:05
Location : First FI Gold House Recep Received: 03/03/2016 @ 09:55
Radon Level : **0.7 pCi/L** Analyzed: 03/03/2016 @ 17:18



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2402770
Canister Type : Charcoal Canister 3 inch
Location : First FI Nurse-Main Open
Radon Level : **0.5 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 13:20
Test Stop : 02/25/2016 @ 14:59
Received: 03/03/2016 @ 09:55
Analyzed: 03/04/2016 @ 10:43

Canister ID# : 2402773
Canister Type : Charcoal Canister 3 inch
Location : First FI 5
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 13:27
Test Stop : 02/25/2016 @ 15:02
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:53

Canister ID# : 2402774
Canister Type : Charcoal Canister 3 inch
Location : First FI 2 Open
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.1 pCi/L

Test Start : 02/22/2016 @ 13:29
Test Stop : 02/25/2016 @ 15:03
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:04

Canister ID# : 2402775
Canister Type : Charcoal Canister 3 inch
Location : First FI 116
Radon Level : **0.6 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 13:14
Test Stop : 02/25/2016 @ 14:56
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:40

Canister ID# : 2402776
Canister Type : Charcoal Canister 3 inch
Location : First FI 87 Open
Radon Level : **0.8 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 12:17
Test Stop : 02/25/2016 @ 14:24
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:11

Canister ID# : 2402778
Canister Type : Charcoal Canister 3 inch
Location : First FI Cafe
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 13:04
Test Stop : 02/25/2016 @ 14:50
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:36

Canister ID# : 2402780
Canister Type : Charcoal Canister 3 inch
Location : First FI Womens PE Office Open
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.9 pCi/L

Test Start : 02/22/2016 @ 12:45
Test Stop : 02/25/2016 @ 14:39
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:40



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2402781 Test Start : 02/22/2016 @ 10:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:07
Location : First FI Counseling Office Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 16:30
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402783 Test Start : 02/22/2016 @ 11:46
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:06
Location : First FI Gold House Office Received: 03/03/2016 @ 09:55
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 15:53
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402785 Test Start : 02/22/2016 @ 13:32
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:04
Location : First FI 6 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:23
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402786 Test Start : 02/22/2016 @ 13:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:55
Location : First FI 119 Office Received: 03/03/2016 @ 09:55
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 14:23
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402787 Test Start : 02/22/2016 @ 13:34
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:06
Location : First FI 11 Office Received: 03/03/2016 @ 09:55
Radon Level : **0.4 pCi/L** Analyzed: 03/03/2016 @ 14:55
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402788 Test Start : 02/22/2016 @ 12:46
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:40
Location : First FI WTA Office Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 16:48
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2402789 Test Start : 02/22/2016 @ 11:59
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:15
Location : First FI 85 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 16:10
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2402790 Test Start : 02/22/2016 @ 13:13
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:56
Location : First FI 118/116 Office Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:53



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2402792
Canister Type : Charcoal Canister 3 inch
Location : First FI Womens PE Office
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 12:45
Test Stop : 02/25/2016 @ 14:39
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48

Canister ID# : 2402793
Canister Type : Charcoal Canister 3 inch
Location : First FI 51 Storage Open
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 11:28
Test Stop : 02/25/2016 @ 13:55
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:09

Canister ID# : 2402794
Canister Type : Charcoal Canister 3 inch
Location : First FI 100
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 12:54
Test Stop : 02/25/2016 @ 14:46
Received: 03/03/2016 @ 09:55
Analyzed: 03/04/2016 @ 10:43

Canister ID# : 2402795
Canister Type : Charcoal Canister 3 inch
Location : First FI 189
Radon Level : **0.6 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:05
Test Stop : 02/25/2016 @ 13:25
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:36

Canister ID# : 2402796
Canister Type : Charcoal Canister 3 inch
Location : First FI Weight Rm
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.9 pCi/L

Test Start : 02/22/2016 @ 12:25
Test Stop : 02/25/2016 @ 14:27
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48

Canister ID# : 2402797
Canister Type : Charcoal Canister 3 inch
Location : First FI Blue House Office
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 10:44
Test Stop : 02/25/2016 @ 13:13
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 14:55

Canister ID# : 2402798
Canister Type : Charcoal Canister 3 inch
Location : First FI Counseling Conf Rm Op
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 10:24
Test Stop : 02/25/2016 @ 13:06
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:35



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2402799 Test Start : 02/22/2016 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:10
Location : First FI Test Center Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 16:10
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402800 Test Start : 02/22/2016 @ 12:55
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:48
Location : First FI Cafeteria Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:55
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2402802 Test Start : 02/22/2016 @ 13:22
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:00
Location : First FI Security Received: 03/03/2016 @ 09:55
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 17:53
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2402803 Test Start : 02/22/2016 @ 11:31
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:58
Location : First FI 52 Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 15:09
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2403294 Test Start : 02/22/2016 @ 11:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:02
Location : First FI Faculty Rm Received: 03/03/2016 @ 09:54
Radon Level : **0.5 pCi/L** Analyzed: 03/03/2016 @ 15:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2403306 Test Start : 02/22/2016 @ 11:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:41
Location : First FI 129 Received: 03/03/2016 @ 09:54
Radon Level : **0.6 pCi/L** Analyzed: 03/03/2016 @ 16:48
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2403694 Test Start : 02/22/2016 @ 13:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:07
Location : Blank Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/04/2016 @ 10:24
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2403702 Test Start : 02/22/2016 @ 13:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:07
Location : Blank Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/04/2016 @ 10:24



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2403731
Canister Type : Charcoal Canister 3 inch
Location : Blank
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 13:35
Test Stop : 02/25/2016 @ 15:07
Received: 03/03/2016 @ 09:55
Analyzed: 03/04/2016 @ 10:24

Canister ID# : 2403756
Canister Type : Charcoal Canister 3 inch
Location : Blank
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.9 pCi/L

Test Start : 02/22/2016 @ 13:35
Test Stop : 02/25/2016 @ 15:07
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:08

Canister ID# : 2403766
Canister Type : Charcoal Canister 3 inch
Location : Blank
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 02/22/2016 @ 13:35
Test Stop : 02/25/2016 @ 15:07
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:34

Canister ID# : 2403789
Canister Type : Charcoal Canister 3 inch
Location :
Radon Level : **0.5 pCi/L**
Error for Measurement is: \pm 0.7 pCi/L

Test Start : 02/22/2016 @ 13:35
Test Stop : 02/25/2016 @ 15:07
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:53

Canister ID# : 2403804
Canister Type : Charcoal Canister 3 inch
Location : Blank
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 13:35
Test Stop : 02/25/2016 @ 15:07
Received: 03/03/2016 @ 09:55
Analyzed: 03/04/2016 @ 10:24

Canister ID# : 2403811
Canister Type : Charcoal Canister 3 inch
Location : Blank
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 02/22/2016 @ 13:35
Test Stop : 02/25/2016 @ 15:07
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:08

Canister ID# : 2404101
Canister Type : Charcoal Canister 3 inch
Location : First FI Office Across from 98
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 02/22/2016 @ 12:53
Test Stop : 02/25/2016 @ 14:46
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:23



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2404103 Test Start : 02/22/2016 @ 12:01
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:18
Location : First FI 77 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:04
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2404104 Test Start : 02/22/2016 @ 11:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:40
Location : First FI 126 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404105 Test Start : 02/22/2016 @ 10:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:55
Location : First FI A125 Received: 03/03/2016 @ 09:54
Radon Level : **0.4 pCi/L** Analyzed: 03/04/2016 @ 10:43
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404111 Test Start : 02/22/2016 @ 11:44
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:05
Location : First FI Gold House Office Received: 03/03/2016 @ 09:55
Radon Level : **0.5 pCi/L** Analyzed: 03/03/2016 @ 15:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404114 Test Start : 02/22/2016 @ 12:00
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:17
Location : First FI 81 Received: 03/03/2016 @ 09:55
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 15:54
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2404115 Test Start : 02/22/2016 @ 12:21
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:27
Location : First FI Field House Received: 03/03/2016 @ 09:55
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 15:09
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404116 Test Start : 02/22/2016 @ 11:48
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:07
Location : First FI Gold House Office Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:04
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404120 Test Start : 02/22/2016 @ 10:49
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:18
Location : First FI 211 Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 17:18



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2404121
Canister Type : Charcoal Canister 3 inch
Location : First FI 18
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 02/22/2016 @ 09:53
Test Stop : 02/25/2016 @ 12:42
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:34

Canister ID# : 2404122
Canister Type : Charcoal Canister 3 inch
Location : First FI Security
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 13:22
Test Stop : 02/25/2016 @ 15:00
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:40

Canister ID# : 2404125
Canister Type : Charcoal Canister 3 inch
Location : First FI 82
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 12:06
Test Stop : 02/25/2016 @ 14:23
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:10

Canister ID# : 2404126
Canister Type : Charcoal Canister 3 inch
Location : First FI 67 Open
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:55
Test Stop : 02/25/2016 @ 14:10
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:18

Canister ID# : 2404127
Canister Type : Charcoal Canister 3 inch
Location : First FI 4 Open
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 13:31
Test Stop : 02/25/2016 @ 15:03
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:35

Canister ID# : 2404129
Canister Type : Charcoal Canister 3 inch
Location : First FI 61
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.1 pCi/L

Test Start : 02/22/2016 @ 11:41
Test Stop : 02/25/2016 @ 14:03
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:10

Canister ID# : 2404131
Canister Type : Charcoal Canister 3 inch
Location : First FI 48S
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:23
Test Stop : 02/25/2016 @ 13:53
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 16:10



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2404135 Test Start : 02/22/2016 @ 12:52
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:44
Location : First FI 101 Boys PE Office Received: 03/03/2016 @ 09:55
Radon Level : **0.4 pCi/L** Analyzed: 03/03/2016 @ 17:18
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404137 Test Start : 02/22/2016 @ 13:16
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:58
Location : First FI 112 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:18
Error for Measurement is: ± 0.1 pCi/L

Canister ID# : 2404138 Test Start : 02/22/2016 @ 11:49
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:08
Location : First FI Gold House Office Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:18
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404139 Test Start : 02/22/2016 @ 10:42
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:13
Location : First FI Blue House Office Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:23
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404140 Test Start : 02/22/2016 @ 10:01
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:50
Location : First FI Stage On Ground Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 14:54
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404141 Test Start : 02/22/2016 @ 10:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:06
Location : First FI Counseling Recep Received: 03/03/2016 @ 09:54
Radon Level : **0.4 pCi/L** Analyzed: 03/04/2016 @ 10:43
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404142 Test Start : 02/22/2016 @ 10:52
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:19
Location : First FI 207 Received: 03/03/2016 @ 09:54
Radon Level : **0.6 pCi/L** Analyzed: 03/03/2016 @ 15:35
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404143 Test Start : 02/22/2016 @ 09:58
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:45
Location : First FI 30 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:53



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2404147
Canister Type : Charcoal Canister 3 inch
Location : First FI Cafe
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 13:04
Test Stop : 02/25/2016 @ 14:50
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 14:40

Canister ID# : 2404148
Canister Type : Charcoal Canister 3 inch
Location : First FI 89
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 02/22/2016 @ 12:17
Test Stop : 02/25/2016 @ 14:25
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:53

Canister ID# : 2404149
Canister Type : Charcoal Canister 3 inch
Location : First FI 33A
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.7 pCi/L

Test Start : 02/22/2016 @ 10:16
Test Stop : 02/25/2016 @ 13:01
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 16:48

Canister ID# : 2404150
Canister Type : Charcoal Canister 3 inch
Location : First FI 24
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 09:56
Test Stop : 02/25/2016 @ 12:43
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:18

Canister ID# : 2404151
Canister Type : Charcoal Canister 3 inch
Location : First FI 44
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 10:22
Test Stop : 02/25/2016 @ 13:05
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 14:40

Canister ID# : 2404152
Canister Type : Charcoal Canister 3 inch
Location : First FI Lib Office
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 11:14
Test Stop : 02/25/2016 @ 13:44
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 14:40

Canister ID# : 2404154
Canister Type : Charcoal Canister 3 inch
Location : First FI LGI-C122
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:11
Test Stop : 02/25/2016 @ 13:43
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 14:40



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2404159 Test Start : 02/22/2016 @ 10:42
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:13
Location : First FI Blue House Office Received: 03/03/2016 @ 09:54
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 16:30
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2404161 Test Start : 02/22/2016 @ 10:14
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:59
Location : First FI Faculty Room Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 16:10
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2404167 Test Start : 02/22/2016 @ 11:34
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:01
Location : First FI 57 Storage Received: 03/03/2016 @ 09:55
Radon Level : **0.9 pCi/L** Analyzed: 03/04/2016 @ 11:01
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404169 Test Start : 02/22/2016 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:10
Location : First FI Test Center Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:40
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404171 Test Start : 02/22/2016 @ 11:51
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:09
Location : First FI Gold House Office Received: 03/03/2016 @ 09:55
Radon Level : **0.4 pCi/L** Analyzed: 03/04/2016 @ 10:24
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404173 Test Start : 02/22/2016 @ 09:58
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:45
Location : First FI 30 Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 17:53
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2404176 Test Start : 02/22/2016 @ 10:12
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:56
Location : First FI 31 Open Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 16:30
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404177 Test Start : 02/22/2016 @ 09:52
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:41
Location : First FI 16 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 15:36



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2404179
Canister Type : Charcoal Canister 3 inch
Location : First FI Tech Office
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.8 pCi/L

Test Start : 02/22/2016 @ 12:56
Test Stop : 02/25/2016 @ 14:47
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:30

Canister ID# : 2404182
Canister Type : Charcoal Canister 3 inch
Location : First FI 123
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:07
Test Stop : 02/25/2016 @ 13:40
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:18

Canister ID# : 2404183
Canister Type : Charcoal Canister 3 inch
Location : First FI 202
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 10:45
Test Stop : 02/25/2016 @ 13:14
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:53

Canister ID# : 2404185
Canister Type : Charcoal Canister 3 inch
Location : First FI 80/82 Storage
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 12:06
Test Stop : 02/25/2016 @ 14:23
Received: 03/03/2016 @ 09:55
Analyzed: 03/04/2016 @ 10:24

Canister ID# : 2404188
Canister Type : Charcoal Canister 3 inch
Location : First FI 80
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 12:05
Test Stop : 02/25/2016 @ 14:22
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:30

Canister ID# : 2404191
Canister Type : Charcoal Canister 3 inch
Location : First FI Nurse-Cot Area
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.1 pCi/L

Test Start : 02/22/2016 @ 13:20
Test Stop : 02/25/2016 @ 14:59
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 17:18

Canister ID# : 2404193
Canister Type : Charcoal Canister 3 inch
Location : First FI 26
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 02/22/2016 @ 09:57
Test Stop : 02/25/2016 @ 12:44
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 16:10



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2404194 Test Start : 02/22/2016 @ 13:08
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:54
Location : First FI Custodial Break Open Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:54
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404195 Test Start : 02/22/2016 @ 12:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:25
Location : First FI 91 Received: 03/03/2016 @ 09:55
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 17:04
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404197 Test Start : 02/22/2016 @ 13:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 15:00
Location : First FI Security Office Rear Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 16:10
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2404198 Test Start : 02/22/2016 @ 10:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:02
Location : First FI 35 Received: 03/03/2016 @ 09:54
Radon Level : **0.5 pCi/L** Analyzed: 03/03/2016 @ 17:34
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404202 Test Start : 02/22/2016 @ 09:46
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:40
Location : First FI Principal's Office Received: 03/03/2016 @ 09:54
Radon Level : **1.1 pCi/L** Analyzed: 03/04/2016 @ 10:24
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404203 Test Start : 02/22/2016 @ 10:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:54
Location : First FI 123 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:53
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404204 Test Start : 02/22/2016 @ 12:50
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:42
Location : First FI 96 Front Received: 03/03/2016 @ 09:55
Radon Level : **0.4 pCi/L** Analyzed: 03/03/2016 @ 15:09
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2404207 Test Start : 02/22/2016 @ 11:03
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:23
Location : First FI 195 Received: 03/03/2016 @ 09:54
Radon Level : **0.5 pCi/L** Analyzed: 03/03/2016 @ 16:48



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2404208
Canister Type : Charcoal Canister 3 inch
Location : First FI AV/TV Office
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 11:20
Test Stop : 02/25/2016 @ 13:49
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:18

Canister ID# : 2404210
Canister Type : Charcoal Canister 3 inch
Location : First FI 49 Art
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:22
Test Stop : 02/25/2016 @ 13:55
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:34

Canister ID# : 2404211
Canister Type : Charcoal Canister 3 inch
Location : First FI 98 Open
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 12:52
Test Stop : 02/25/2016 @ 14:44
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48

Canister ID# : 2404213
Canister Type : Charcoal Canister 3 inch
Location : First FI 25
Radon Level : **0.6 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 10:06
Test Stop : 02/25/2016 @ 12:52
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:09

Canister ID# : 2404223
Canister Type : Charcoal Canister 3 inch
Location : First FI 56
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 11:35
Test Stop : 02/25/2016 @ 14:02
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:35

Canister ID# : 2404225
Canister Type : Charcoal Canister 3 inch
Location : First FI 29
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 02/22/2016 @ 10:12
Test Stop : 02/25/2016 @ 12:56
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 14:23

Canister ID# : 2404231
Canister Type : Charcoal Canister 3 inch
Location : First FI 57 Storage
Radon Level : **0.1 pCi/L**
Moved to 53--Void

Test Start : 02/22/2016 @ 11:34
Test Stop : 02/25/2016 @ 13:57
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48

Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2404234 Test Start : 02/22/2016 @ 10:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:54
Location : First FI 123 Received: 03/03/2016 @ 09:54
Radon Level : **0.4 pCi/L** Analyzed: 03/04/2016 @ 10:43
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404236 Test Start : 02/22/2016 @ 10:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:12
Location : First FI Blue House Recep Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 17:04
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2404237 Test Start : 02/22/2016 @ 10:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:06
Location : First FI Counseling Office Open Received: 03/03/2016 @ 09:54
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 14:40
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404242 Test Start : 02/22/2016 @ 11:08
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:40
Location : First FI 125 Received: 03/03/2016 @ 09:54
Radon Level : **0.2 pCi/L** Analyzed: 03/03/2016 @ 16:48
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404244 Test Start : 02/22/2016 @ 12:06
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:23
Location : First FI 82 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 15:53
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2404245 Test Start : 02/22/2016 @ 11:30
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:56
Location : First FI 53 Front by Screen Received: 03/03/2016 @ 09:54
Radon Level : **0.6 pCi/L** Analyzed: 03/03/2016 @ 17:18
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404246 Test Start : 02/22/2016 @ 09:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:40
Location : First FI Mail Room Received: 03/03/2016 @ 09:54
Radon Level : **0.3 pCi/L** Analyzed: 03/04/2016 @ 10:43
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404248 Test Start : 02/22/2016 @ 12:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:40
Location : First FI 92 Received: 03/03/2016 @ 09:55
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 17:18



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2404252
Canister Type : Charcoal Canister 3 inch
Location : First FI 206
Radon Level : **0.5 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 10:47
Test Stop : 02/25/2016 @ 13:15
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:18

Canister ID# : 2404260
Canister Type : Charcoal Canister 3 inch
Location : First FI 57
Radon Level : **0.7 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:33
Test Stop : 02/25/2016 @ 14:01
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48

Canister ID# : 2404261
Canister Type : Charcoal Canister 3 inch
Location : First FI Gold House Office
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:48
Test Stop : 02/25/2016 @ 14:07
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 16:48

Canister ID# : 2404264
Canister Type : Charcoal Canister 3 inch
Location : First FI 126
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 11:09
Test Stop : 02/25/2016 @ 13:40
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:09

Canister ID# : 2404265
Canister Type : Charcoal Canister 3 inch
Location : First FI Concession Stand
Radon Level : **0.5 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 12:34
Test Stop : 02/25/2016 @ 14:35
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:09

Canister ID# : 2404269
Canister Type : Charcoal Canister 3 inch
Location : First FI Gold House Office
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:47
Test Stop : 02/25/2016 @ 14:07
Received: 03/03/2016 @ 09:55
Analyzed: 03/04/2016 @ 10:24

Canister ID# : 2404277
Canister Type : Charcoal Canister 3 inch
Location : First FI 32
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 02/22/2016 @ 09:59
Test Stop : 02/25/2016 @ 12:45
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:53



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2404278 Test Start : 02/22/2016 @ 10:56
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:20
Location : First FI 201 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:23
Error for Measurement is: ± 2.6 pCi/L

Canister ID# : 2404279 Test Start : 02/22/2016 @ 11:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 14:07
Location : First FI Gold House Office Received: 03/03/2016 @ 09:55
Radon Level : **0.5 pCi/L** Analyzed: 03/03/2016 @ 15:53
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2404281 Test Start : 02/22/2016 @ 10:34
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:09
Location : First FI 45W Received: 03/03/2016 @ 09:54
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 14:40
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2404292 Test Start : 02/22/2016 @ 11:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:49
Location : First FI 48 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 15:09
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2404293 Test Start : 02/22/2016 @ 10:03
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 12:50
Location : First FI Aud Received: 03/03/2016 @ 09:54
Radon Level : **0.3 pCi/L** Analyzed: 03/03/2016 @ 16:30
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2404295 Test Start : 02/22/2016 @ 10:46
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:15
Location : First FI 204 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 16:10
Error for Measurement is: ± 0.1 pCi/L

Canister ID# : 2404298 Test Start : 02/22/2016 @ 11:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:42
Location : First FI Radio WBER Received: 03/03/2016 @ 09:54
Radon Level : **0.5 pCi/L** Analyzed: 03/03/2016 @ 14:54
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2404299 Test Start : 02/22/2016 @ 10:53
Canister Type : Charcoal Canister 3 inch Test Stop : 02/25/2016 @ 13:19
Location : First FI 205 Received: 03/03/2016 @ 09:54
Radon Level : **0.1 pCi/L** Analyzed: 03/03/2016 @ 14:40



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2404302
Canister Type : Charcoal Canister 3 inch
Location : First FI 50 Open
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 11:29
Test Stop : 02/25/2016 @ 13:56
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 14:23

Canister ID# : 2404307
Canister Type : Charcoal Canister 3 inch
Location : First FI 203 Open
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 10:55
Test Stop : 02/25/2016 @ 13:20
Received: 03/03/2016 @ 09:54
Analyzed: 03/04/2016 @ 10:43

Canister ID# : 2404309
Canister Type : Charcoal Canister 3 inch
Location : First FI Counseling Office
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.1 pCi/L

Test Start : 02/22/2016 @ 10:26
Test Stop : 02/25/2016 @ 13:08
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:34

Canister ID# : 2404312
Canister Type : Charcoal Canister 3 inch
Location : First FI 65
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 11:43
Test Stop : 02/25/2016 @ 14:04
Received: 03/03/2016 @ 09:55
Analyzed: 03/04/2016 @ 10:43

Canister ID# : 2404319
Canister Type : Charcoal Canister 3 inch
Location : First FI Tech Office
Radon Level : **0.9 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 12:57
Test Stop : 02/25/2016 @ 14:47
Received: 03/03/2016 @ 09:55
Analyzed: 03/03/2016 @ 15:36

Canister ID# : 2404320
Canister Type : Charcoal Canister 3 inch
Location : First FI 27
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 10:11
Test Stop : 02/25/2016 @ 12:56
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 16:30

Canister ID# : 2404332
Canister Type : Charcoal Canister 3 inch
Location : First FI 20
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 09:55
Test Stop : 02/25/2016 @ 12:42
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 15:09



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

Canister ID# : 2404342
Canister Type : Charcoal Canister 3 inch
Location : First FI 121 Open
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 10:08
Test Stop : 02/25/2016 @ 12:53
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:04

Canister ID# : 2404344
Canister Type : Charcoal Canister 3 inch
Location : First FI Radio Club
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 02/22/2016 @ 10:13
Test Stop : 02/25/2016 @ 12:57
Received: 03/03/2016 @ 09:54
Analyzed: 03/04/2016 @ 10:43

Canister ID# : 2404355
Canister Type : Charcoal Canister 3 inch
Location : First FI 126 Open
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 10:09
Test Stop : 02/25/2016 @ 12:54
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 16:30

Canister ID# : 2404378
Canister Type : Charcoal Canister 3 inch
Location : First FI Aud
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 10:03
Test Stop : 02/25/2016 @ 12:50
Received: 03/03/2016 @ 09:54
Analyzed: 03/04/2016 @ 10:43

Canister ID# : 2404393
Canister Type : Charcoal Canister 3 inch
Location : First FI 28
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 02/22/2016 @ 09:59
Test Stop : 02/25/2016 @ 12:45
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:04

Canister ID# : 2404438
Canister Type : Charcoal Canister 3 inch
Location : First FI Library
Radon Level : **0.5 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 02/22/2016 @ 11:16
Test Stop : 02/25/2016 @ 13:46
Received: 03/03/2016 @ 09:54
Analyzed: 03/03/2016 @ 17:18



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/ditguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 3/24/2016



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201