

Site Radon Inspection Report

Date : 12/18/2017

Blaine Cunningham, Manager of B & G  
WEBSTER CSD  
119 South Avenue  
Webster, NY 14580-

Client: Buildings & Grounds  
Test Location: 110 Sanford Street  
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2525390                      Test Start : 12/11/2017 @ 11:53  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:09  
Location : BLANK                      Received: 12/18/2017 @ 16:05  
Radon Level : 0.1 pCi/L                      Analyzed: 12/19/2017 @ 15:09  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2528060                      Test Start : 12/11/2017 @ 09:59  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:03  
Location : 1st FL-Tom Canney Office      Received: 12/18/2017 @ 16:04  
Radon Level : 0.4 pCi/L                      Analyzed: 12/19/2017 @ 15:30  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2528065                      Test Start : 12/11/2017 @ 10:12  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:09  
Location : 1st FL-Susan Smioldo      Received: 12/18/2017 @ 16:05  
Radon Level : 0.3 pCi/L                      Analyzed: 12/19/2017 @ 15:10  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2536107                      Test Start : 12/11/2017 @ 10:09  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:08  
Location : 1st FL-Tech Office Main Area      Received: 12/18/2017 @ 16:05  
Radon Level : 0.4 pCi/L                      Analyzed: 12/19/2017 @ 14:37  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2536127                      Test Start : 12/11/2017 @ 10:11  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:09  
Location : 1st FL-Jeanne Lynch      Received: 12/18/2017 @ 16:05  
Radon Level : 0.2 pCi/L                      Analyzed: 12/19/2017 @ 14:53  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2536133                      Test Start : 12/11/2017 @ 10:06  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:08  
Location : 1st FL-Brenda Roof      Received: 12/18/2017 @ 16:05  
Radon Level : 0.1 pCi/L                      Analyzed: 12/19/2017 @ 14:36  
Error for Measurement is:  $\pm$  0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date :

Blaine Cunningham, Manager of B & G  
WEBSTER CSD  
119 South Avenue  
Webster, NY 14580-

Client: Buildings & Grounds  
Test Location: 110 Sanford Street  
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2540163                      Test Start : 12/11/2017 @ 10:00  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:04  
Location : 1st FL-Energy Mgmt Office      Received: 12/31/-4714 @ 00:00  
Radon Level : 0.7 pCi/L                      Analyzed: 12/19/2017 @ 15:09  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2540185                      Test Start : 12/11/2017 @ 10:04  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:06  
Location : 1st FL-Tech Office Area-rear      Received: 12/18/2017 @ 16:05  
Radon Level : 0.2 pCi/L                      Analyzed: 12/19/2017 @ 14:19  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2540193                      Test Start : 12/11/2017 @ 10:06  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:07  
Location : 1st FL-Joe Montemaro              Received: 12/18/2017 @ 16:05  
Radon Level : 0.4 pCi/L                      Analyzed: 12/19/2017 @ 14:02  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2540194                      Test Start : 12/11/2017 @ 10:01  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:04  
Location : 1st FL-Tech Storage Upper      Received: 12/18/2017 @ 16:05  
Radon Level : 0.1 pCi/L                      Analyzed: 12/19/2017 @ 14:37  
Error for Measurement is:  $\pm$  0.2 pCi/L

Canister ID# : 2540200                      Test Start : 12/11/2017 @ 10:11  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:09  
Location : 1st FL-Blaine Cunningham      Received: 12/18/2017 @ 16:05  
Radon Level : 1.7 pCi/L                      Analyzed: 12/19/2017 @ 15:30  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2540202                      Test Start : 12/11/2017 @ 11:53  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:09  
Location : 1st FL-Conference Rm              Received: 12/18/2017 @ 16:05  
Radon Level : 0.3 pCi/L                      Analyzed: 12/19/2017 @ 14:52  
Error for Measurement is:  $\pm$  0.6 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/18/2017

Blaine Cunningham, Manager of B & G  
WEBSTER CSD  
119 South Avenue  
Webster, NY 14580-

Client: Buildings & Grounds  
Test Location: 110 Sanford Street  
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2540213                      Test Start : 12/11/2017 @ 10:09  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:08  
Location : 1st FL-Tech Office Main Area      Received: 12/18/2017 @ 16:05  
Radon Level : 1.2 pCi/L                      Analyzed: 12/19/2017 @ 15:09  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2540220                      Test Start : 12/11/2017 @ 10:13  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:10  
Location : 1st FL-Chet's Area                  Received: 12/18/2017 @ 16:05  
Radon Level : 0.4 pCi/L                      Analyzed: 12/19/2017 @ 14:37  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2540228                      Test Start : 12/11/2017 @ 10:02  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:05  
Location : 1st FL-CCMA Office                  Received: 12/18/2017 @ 16:05  
Radon Level : 0.2 pCi/L                      Analyzed: 12/19/2017 @ 14:02  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2540251                      Test Start : 12/11/2017 @ 10:11  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:09  
Location : 1st FL-Neil Flood                      Received: 12/18/2017 @ 16:05  
Radon Level : 0.1 pCi/L                      Analyzed: 12/19/2017 @ 16:01  
Error for Measurement is:  $\pm$  0.7 pCi/L

Canister ID# : 2540258                      Test Start : 12/11/2017 @ 10:03  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:05  
Location : 1st FL-Tech Storage Lower          Received: 12/18/2017 @ 16:05  
Radon Level : 0.1 pCi/L                      Analyzed: 12/19/2017 @ 15:09  
Error for Measurement is:  $\pm$  0.8 pCi/L

Canister ID# : 2540782                      Test Start : 12/11/2017 @ 10:05  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/13/2017 @ 13:07  
Location : 1st FL-Bill Blitz                      Received: 12/18/2017 @ 16:05  
Radon Level : 0.6 pCi/L                      Analyzed: 12/19/2017 @ 15:09  
Error for Measurement is:  $\pm$  0.5 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/18/2017

Blaine Cunningham, Manager of B & G  
WEBSTER CSD  
119 South Avenue  
Webster, NY 14580-

Client: Buildings & Grounds  
Test Location: 110 Sanford Street  
Webster, NY 14580-

## Individual Canister Results

|                             |                          |              |                    |
|-----------------------------|--------------------------|--------------|--------------------|
| Canister ID# :              | 2540791                  | Test Start : | 12/11/2017 @ 10:10 |
| Canister Type :             | Charcoal Canister 3 inch | Test Stop :  | 12/13/2017 @ 13:08 |
| Location :                  | 1st FL-Brian Zimmer      | Received:    | 12/18/2017 @ 16:05 |
| Radon Level :               | 0.2 pCi/L                | Analyzed:    | 12/19/2017 @ 15:09 |
| Error for Measurement is: ± | 0.6 pCi/L                |              |                    |

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon ([www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html)). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at [www.epa.gov/iaq/radon](http://www.epa.gov/iaq/radon).

**For New Jersey clients:** Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

**For New York clients:** If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

---

**PLEDGE OF ASSURED QUALITY**

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201