

Site Radon Inspection Report

Date : 12/18/2017

Blaine Cunningham, Manager of B & G
WEBSTER CSD
119 South Avenue
Webster, NY 14580-

Client: Transportation Dept
Test Location: 1000 Document Drive
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2361785 Test Start : 12/11/2017 @ 11:02
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:41
Location : 1st FL-Trans Director Received: 12/18/2017 @ 16:03
Radon Level : 0.1 pCi/L Analyzed: 12/19/2017 @ 14:36
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2361888 Test Start : 12/11/2017 @ 11:08
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:42
Location : 1st FL-Trans Storage Received: 12/18/2017 @ 16:03
Radon Level : 0.1 pCi/L Analyzed: 12/19/2017 @ 14:20
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2525391 Test Start : 12/11/2017 @ 11:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:41
Location : 1st FL-Drivers Rm near Sink Received: 12/18/2017 @ 16:03
Radon Level : 0.5 pCi/L Analyzed: 12/19/2017 @ 15:10
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2536072 Test Start : 12/11/2017 @ 11:07
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:42
Location : 1st FL-Foreman Office Received: 12/18/2017 @ 16:03
Radon Level : 0.3 pCi/L Analyzed: 12/19/2017 @ 14:53
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2536075 Test Start : 12/11/2017 @ 11:04
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:41
Location : 1st FL-Safety & Training Received: 12/18/2017 @ 16:03
Radon Level : 0.1 pCi/L Analyzed: 12/19/2017 @ 15:09
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2540149 Test Start : 12/11/2017 @ 11:08
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:42
Location : 1st FL-Trans Storage Received: 12/18/2017 @ 16:03
Radon Level : 0.1 pCi/L Analyzed: 12/19/2017 @ 15:09
Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/18/2017

Blaine Cunningham, Manager of B & G
WEBSTER CSD
119 South Avenue
Webster, NY 14580-

Client: Transportation Dept
Test Location: 1000 Document Drive
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2540159 Test Start : 12/11/2017 @ 11:01
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:41
Location : 1st FL- Routing Office Received: 12/18/2017 @ 16:03
Radon Level : 0.1 pCi/L Analyzed: 12/19/2017 @ 14:02
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2540184 Test Start : 12/11/2017 @ 11:03
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:41
Location : 1st FL-Trans Reception Received: 12/18/2017 @ 16:03
Radon Level : 0.1 pCi/L Analyzed: 12/19/2017 @ 14:02
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2540190 Test Start : 12/11/2017 @ 11:08
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:42
Location : 1st FL-Training Office Received: 12/18/2017 @ 16:03
Radon Level : 0.1 pCi/L Analyzed: 12/19/2017 @ 14:20
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2540783 Test Start : 12/11/2017 @ 11:08
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:42
Location : BLANK Received: 12/18/2017 @ 16:03
Radon Level : 0.1 pCi/L Analyzed: 12/19/2017 @ 15:09
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2540785 Test Start : 12/11/2017 @ 11:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:42
Location : 1st FL-Driver Room-drink mach Received: 12/18/2017 @ 16:03
Radon Level : 0.5 pCi/L Analyzed: 12/19/2017 @ 14:52
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2540792 Test Start : 12/11/2017 @ 11:04
Canister Type : Charcoal Canister 3 inch Test Stop : 12/13/2017 @ 13:41
Location : 1st FL-Mechanics Lunch Rm Received: 12/18/2017 @ 16:03
Radon Level : 0.4 pCi/L Analyzed: 12/19/2017 @ 15:30
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/18/2017

Blaine Cunningham, Manager of B & G
WEBSTER CSD
119 South Avenue
Webster, NY 14580-

Client: Transportation Dept
Test Location: 1000 Document Drive
Webster, NY 14580-

Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

*Andreas C. George*

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201