

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2349381 Test Start : 02/09/2016 @ 10:31
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:03
Location : First Floor-B115 Received: 02/17/2016 @ 11:07
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2349385 Test Start : 02/09/2016 @ 10:57
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:11
Location : First Floor-Guid Conf Rm Received: 02/17/2016 @ 11:07
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2349390 Test Start : 02/09/2016 @ 11:12
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:21
Location : First Floor-A112 Received: 02/17/2016 @ 11:07
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2349393 Test Start : 02/09/2016 @ 10:17
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:48
Location : First Floor-C105 Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2349403 Test Start : 02/09/2016 @ 10:00
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:34
Location : First Floor-G119 Received: 02/17/2016 @ 11:06
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2349587 Test Start : 02/09/2016 @ 11:27
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:33
Location : Second Floor-C211 Received: 02/17/2016 @ 11:07
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 16:45
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2349591 Test Start : 02/09/2016 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:06
Location : First Floor-B103 Off Received: 02/17/2016 @ 11:07
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2349598 Test Start : 02/09/2016 @ 10:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:55
Location : First Floor-C116 Received: 02/17/2016 @ 11:06
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2349599 Test Start : 02/09/2016 @ 11:08
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:18
Location : First Floor-A102 Received: 02/17/2016 @ 11:07
Radon Level : 1.3 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2349600 Test Start : 02/09/2016 @ 11:07
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:18
Location : First Floor-A105 Received: 02/17/2016 @ 11:07
Radon Level : 1.1 pCi/L Analyzed: 02/18/2016 @ 16:44
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2349606 Test Start : 02/09/2016 @ 10:30
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:57
Location : First Floor-B130 Received: 02/17/2016 @ 11:07
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2350055 Test Start : 02/09/2016 @ 10:04
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:36
Location : First Floor-Kitchen Off Received: 02/17/2016 @ 11:06
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2350057 Test Start : 02/09/2016 @ 09:49
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:25
Location : First Floor-Gym Received: 02/17/2016 @ 11:06
Radon Level : 1.5 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2350058 Test Start : 02/09/2016 @ 11:20
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:27
Location : Second Floor-A208 Received: 02/17/2016 @ 11:07
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 17:21
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2350059 Test Start : 02/09/2016 @ 09:50
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:27
Location : First Floor-Weight Rm Received: 02/17/2016 @ 11:06
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2350062 Test Start : 02/09/2016 @ 09:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:20
Location : First Floor-Lib Video Rm Received: 02/17/2016 @ 11:06
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2350063 Test Start : 02/09/2016 @ 11:25
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:31
Location : Second Floor-B204 Received: 02/17/2016 @ 11:07
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2350067 Test Start : 02/09/2016 @ 11:01
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:15
Location : First Floor-B122 Received: 02/17/2016 @ 11:07
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2354678 Test Start : 02/09/2016 @ 10:34
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:05
Location : First Floor-B103 Recep Received: 02/17/2016 @ 11:07
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2354679 Test Start : 02/09/2016 @ 10:12
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:39
Location : First Floor-C123 Received: 02/17/2016 @ 11:06
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2355064 Test Start : 02/09/2016 @ 10:36
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:07
Location : First Floor-B107 Received: 02/17/2016 @ 11:07
Radon Level : 1.1 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2356581 Test Start : 02/09/2016 @ 09:28
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:12
Location : First Floor-D105 Rear Off Received: 02/17/2016 @ 11:06
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2356586 Test Start : 02/09/2016 @ 11:21
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:28
Location : Second Floor-A202 Received: 02/17/2016 @ 11:07
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2356590 Test Start : 02/09/2016 @ 10:32
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:03
Location : First Floor-B113 Received: 02/17/2016 @ 11:07
Radon Level : 1.2 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2356599 Test Start : 02/09/2016 @ 11:04
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:16
Location : First Floor-A126 Received: 02/17/2016 @ 11:07
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 12:53
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2360404 Test Start : 02/09/2016 @ 10:27
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:56
Location : First Floor-Support Serv Office Received: 02/17/2016 @ 11:06
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:52
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2360405 Test Start : 02/09/2016 @ 10:24
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:54
Location : First Floor-C114 Received: 02/17/2016 @ 11:06
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2360409 Test Start : 02/09/2016 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:07
Location : First Floor-B106 Received: 02/17/2016 @ 11:07
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2360415 Test Start : 02/09/2016 @ 11:21
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:28
Location : Second Floor-A202 Received: 02/17/2016 @ 11:07
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 12:52
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2360418 Test Start : 02/09/2016 @ 09:47
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:23
Location : First Floor-Girls PE Off Received: 02/17/2016 @ 11:06
Radon Level : 1.1 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2360420 Test Start : 02/09/2016 @ 10:14
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:46
Location : First Floor-C115 Received: 02/17/2016 @ 11:06
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2360424 Test Start : 02/09/2016 @ 09:36
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:15
Location : First Floor-E116 Rear Received: 02/17/2016 @ 11:06
Radon Level : 1.5 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2360425 Test Start : 02/09/2016 @ 10:05
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:36
Location : First Floor-KitchenStpr/Break R Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2360427 Test Start : 02/09/2016 @ 10:01
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:34
Location : First Floor-G112 Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2360565 Test Start : 02/09/2016 @ 10:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:53
Location : First Floor-C111A Received: 02/17/2016 @ 11:06
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2360705 Test Start : 02/09/2016 @ 10:56
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:10
Location : First Floor-B117 Off Received: 02/17/2016 @ 11:07
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 17:21
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2361205 Test Start : 02/09/2016 @ 11:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:19
Location : First Floor-A103 Recept Received: 02/17/2016 @ 11:07
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361242 Test Start : 02/09/2016 @ 10:26
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:55
Location : First Floor-Support Serv Recept Received: 02/17/2016 @ 11:06
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2362907 Test Start : 02/09/2016 @ 10:01
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:34
Location : First Floor-G112 Received: 02/17/2016 @ 11:06
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2362916 Test Start : 02/09/2016 @ 09:50
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:26
Location : First Floor-Gym Received: 02/17/2016 @ 11:06
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2366143 Test Start : 02/09/2016 @ 11:07
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:17
Location : First Floor-A110 Received: 02/17/2016 @ 11:07
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2366145 Test Start : 02/09/2016 @ 11:06
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:17
Location : First Floor-A113 Received: 02/17/2016 @ 11:07
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2366150 Test Start : 02/09/2016 @ 11:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:19
Location : First Floor-A103 Stor Received: 02/17/2016 @ 11:07
Radon Level : 1.2 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2366154 Test Start : 02/09/2016 @ 10:57
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:11
Location : First Floor-B124 Received: 02/17/2016 @ 11:07
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366160 Test Start : 02/09/2016 @ 10:02
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:35
Location : First Floor-G114 Received: 02/17/2016 @ 11:06
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366179 Test Start : 02/09/2016 @ 10:54
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:08
Location : First Floor-B114 Received: 02/17/2016 @ 11:07
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2366183 Test Start : 02/09/2016 @ 10:19
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:51
Location : First Floor-C Wing Off Rec Received: 02/17/2016 @ 11:06
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2366190 Test Start : 02/09/2016 @ 10:57
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:12
Location : First Floor-Guid Recep Received: 02/17/2016 @ 11:07
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2366458 Test Start : 02/09/2016 @ 09:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:19
Location : First Floor-Lib Received: 02/17/2016 @ 11:06
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2366463 Test Start : 02/09/2016 @ 09:40
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:17
Location : First Floor-E104 Received: 02/17/2016 @ 11:06
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 14:31
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2366466 Test Start : 02/09/2016 @ 10:20
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:51
Location : First Floor-C Wing Off Received: 02/17/2016 @ 11:06
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2367040 Test Start : 02/09/2016 @ 10:33
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:04
Location : First Floor-B105 Received: 02/17/2016 @ 11:07
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2367047 Test Start : 02/09/2016 @ 10:28
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:56
Location : First Floor-Support Serv Off Received: 02/17/2016 @ 11:07
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2367052 Test Start : 02/09/2016 @ 11:29
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:34
Location : BL Received: 02/17/2016 @ 11:07
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2367057 Test Start : 02/09/2016 @ 09:37
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:16
Location : First Floor-E106/E105 Received: 02/17/2016 @ 11:06
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2367061 Test Start : 02/09/2016 @ 09:51
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:27
Location : First Floor-Boys PE Off Received: 02/17/2016 @ 11:06
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2367067 Test Start : 02/09/2016 @ 10:55
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:09
Location : First Floor-B117 Kitchen Received: 02/17/2016 @ 11:07
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2367249 Test Start : 02/09/2016 @ 09:46
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:22
Location : First Floor-Storage PE Off Received: 02/17/2016 @ 11:06
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2367255 Test Start : 02/09/2016 @ 09:51
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:27
Location : First Floor-Boys PE Off Received: 02/17/2016 @ 11:06
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2367256 Test Start : 02/09/2016 @ 11:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:30
Location : Second Floor-B210 Received: 02/17/2016 @ 11:07
Radon Level : 0.3 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2367263 Test Start : 02/09/2016 @ 09:51
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:28
Location : First Floor-Storage PE Off Received: 02/17/2016 @ 11:06
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2367264 Test Start : 02/09/2016 @ 10:17
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:47
Location : First Floor-C110 Received: 02/17/2016 @ 11:06
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2367266 Test Start : 02/09/2016 @ 11:28
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:33
Location : Second Floor-C206 Received: 02/17/2016 @ 11:07
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2367267 Test Start : 02/09/2016 @ 11:14
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:24
Location : First Floor-A117 Hearing Rm Received: 02/17/2016 @ 11:07
Radon Level : 1.2 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2374305 Test Start : 02/09/2016 @ 09:42
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:21
Location : First Floor-Lib Copy Rm-E115A Received: 02/17/2016 @ 11:06
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 14:32
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2396300 Test Start : 02/09/2016 @ 10:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:37
Location : First Floor-Cafe Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 15:27
Error for Measurement is: ± 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396310 Test Start : 02/09/2016 @ 09:30
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:12
Location : First Floor-D106 Received: 02/17/2016 @ 11:06
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2396328 Test Start : 02/09/2016 @ 09:48
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:24
Location : First Floor-Gym Received: 02/17/2016 @ 11:06
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396331 Test Start : 02/09/2016 @ 10:28
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:56
Location : First Floor-Support Serv Off Received: 02/17/2016 @ 11:06
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2396333 Test Start : 02/09/2016 @ 11:29
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:34
Location : BL Received: 02/17/2016 @ 11:07
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396335 Test Start : 02/09/2016 @ 09:55
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:29
Location : First Floor-G109 Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396336 Test Start : 02/09/2016 @ 09:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:14
Location : First Floor-E116-Av Off Received: 02/17/2016 @ 11:06
Radon Level : 1.9 pCi/L Analyzed: 02/18/2016 @ 17:03
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	2396364	Test Start :	02/09/2016 @ 10:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/12/2016 @ 12:05
Location :	First Floor-B102	Received:	02/17/2016 @ 11:07
Radon Level :	0.7 pCi/L	Analyzed:	02/18/2016 @ 15:42
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	2396368	Test Start :	02/09/2016 @ 09:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/12/2016 @ 11:09
Location :	First Floor-Main Off	Received:	02/17/2016 @ 11:06
Radon Level :	0.3 pCi/L	Analyzed:	02/18/2016 @ 13:23
Error for Measurement is:	\pm 0.3 pCi/L		

Canister ID# :	2396369	Test Start :	02/09/2016 @ 11:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/12/2016 @ 12:34
Location :	BL	Received:	02/17/2016 @ 11:07
Radon Level :	0.1 pCi/L	Analyzed:	02/18/2016 @ 16:44
Error for Measurement is:	\pm 0.6 pCi/L		

Canister ID# :	2396585	Test Start :	02/09/2016 @ 09:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/12/2016 @ 11:34
Location :	First Floor-G113 Band	Received:	02/17/2016 @ 11:06
Radon Level :	0.1 pCi/L	Analyzed:	02/18/2016 @ 17:21
Error for Measurement is:	\pm 0.6 pCi/L		

Canister ID# :	2396586	Test Start :	02/09/2016 @ 11:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/12/2016 @ 12:34
Location :	BL	Received:	02/17/2016 @ 11:07
Radon Level :	0.1 pCi/L	Analyzed:	02/18/2016 @ 14:09
Error for Measurement is:	\pm 0.3 pCi/L		

Canister ID# :	2396588	Test Start :	02/09/2016 @ 11:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	02/12/2016 @ 12:34
Location :	BL	Received:	02/17/2016 @ 11:07
Radon Level :	0.1 pCi/L	Analyzed:	02/18/2016 @ 15:42
Error for Measurement is:	\pm 0.4 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396590 Test Start : 02/09/2016 @ 09:57
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:32
Location : First Floor-G111 Stor Received: 02/17/2016 @ 11:06
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 12:52
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2396594 Test Start : 02/09/2016 @ 10:18
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:48
Location : First Floor-C102 Received: 02/17/2016 @ 11:06
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 17:21
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396597 Test Start : 02/09/2016 @ 09:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:19
Location : First Floor-Lib Received: 02/17/2016 @ 11:06
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396598 Test Start : 02/09/2016 @ 11:14
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:24
Location : First Floor-A117 Main Received: 02/17/2016 @ 11:07
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2396600 Test Start : 02/09/2016 @ 10:11
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:38
Location : First Floor-Sec Off Received: 02/17/2016 @ 11:06
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396601 Test Start : 02/09/2016 @ 09:41
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:20
Location : First Floor-Lib Video Rm Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 14:31
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396602 Test Start : 02/09/2016 @ 10:08
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:37
Location : First Floor-Cafe Received: 02/17/2016 @ 11:06
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396605 Test Start : 02/09/2016 @ 09:57
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:31
Location : First Floor-G111 Received: 02/17/2016 @ 11:06
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 14:31
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396606 Test Start : 02/09/2016 @ 09:58
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:33
Location : First Floor-Stage Received: 02/17/2016 @ 11:06
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396608 Test Start : 02/09/2016 @ 09:39
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:16
Location : First Floor-E105 Received: 02/17/2016 @ 11:06
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2396609 Test Start : 02/09/2016 @ 10:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:38
Location : First Floor-Cust Off Received: 02/17/2016 @ 11:06
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2396610 Test Start : 02/09/2016 @ 10:15
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:47
Location : First Floor-C113 Received: 02/17/2016 @ 11:06
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396612 Test Start : 02/09/2016 @ 09:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:10
Location : First Floor-Main Off Kitch Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2396618 Test Start : 02/09/2016 @ 09:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:09
Location : First Floor-Princ Off Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396742 Test Start : 02/09/2016 @ 10:37
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:10
Location : First Floor-B111A Received: 02/17/2016 @ 11:07
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 15:27
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2396787 Test Start : 02/09/2016 @ 11:11
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:20
Location : First Floor-A107 Received: 02/17/2016 @ 11:07
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2396793 Test Start : 02/09/2016 @ 11:09
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:19
Location : First Floor-A103 Off Received: 02/17/2016 @ 11:07
Radon Level : 1.3 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2396802 Test Start : 02/09/2016 @ 11:10
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:20
Location : First Floor-A106 Received: 02/17/2016 @ 11:07
Radon Level : 1.4 pCi/L Analyzed: 02/18/2016 @ 14:31
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396837 Test Start : 02/09/2016 @ 11:11
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:20
Location : First Floor-A107 Received: 02/17/2016 @ 11:07
Radon Level : 1.1 pCi/L Analyzed: 02/18/2016 @ 14:31
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396838 Test Start : 02/09/2016 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:06
Location : First Floor-B103 Stor Received: 02/17/2016 @ 11:07
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 17:21
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396875 Test Start : 02/09/2016 @ 10:56
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:11
Location : First Floor-B118 Received: 02/17/2016 @ 11:07
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 14:51
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396880 Test Start : 02/09/2016 @ 11:11
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:21
Location : First Floor-A111A Received: 02/17/2016 @ 11:07
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2398452 Test Start : 02/09/2016 @ 10:14
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:46
Location : First Floor-C115 Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2401524 Test Start : 02/09/2016 @ 10:53
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:08
Location : First Floor-B112 Received: 02/17/2016 @ 11:07
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2402747 Test Start : 02/09/2016 @ 11:00
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:14
Location : First Floor-B120 Received: 02/17/2016 @ 11:07
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2403676 Test Start : 02/09/2016 @ 09:34
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:10
Location : First Floor-E114 Received: 02/17/2016 @ 11:06
Radon Level : 1.0 pCi/L Analyzed: 02/18/2016 @ 15:27
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2403689 Test Start : 02/09/2016 @ 11:06
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:16
Location : First Floor-A115 Received: 02/17/2016 @ 11:07
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 15:42
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2403730 Test Start : 02/09/2016 @ 09:36
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:15
Location : First Floor-E116 Rear Off Received: 02/17/2016 @ 11:06
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 12:35
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2403737 Test Start : 02/09/2016 @ 09:27
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:12
Location : First Floor-D103 Received: 02/17/2016 @ 11:06
Radon Level : 1.4 pCi/L Analyzed: 02/18/2016 @ 13:39
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2403746 Test Start : 02/09/2016 @ 10:21
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:52
Location : First Floor-C106 Received: 02/17/2016 @ 11:06
Radon Level : 0.6 pCi/L Analyzed: 02/18/2016 @ 16:45
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2403754 Test Start : 02/09/2016 @ 11:20
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:28
Location : Second Floor-A207 Received: 02/17/2016 @ 11:07
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 15:12
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2403765 Test Start : 02/09/2016 @ 11:13
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:23
Location : First Floor-A114 Received: 02/17/2016 @ 11:07
Radon Level : 1.2 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2403776 Test Start : 02/09/2016 @ 11:30
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:34
Location : Second Floor-C218 Received: 02/17/2016 @ 11:07
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 12:52
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2403786 Test Start : 02/09/2016 @ 09:29
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:12
Location : First Floor-D106/D105 Off Received: 02/17/2016 @ 11:06
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 15:59
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2403788 Test Start : 02/09/2016 @ 11:19
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:27
Location : Second Floor-A211 Received: 02/17/2016 @ 11:07
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2403796 Test Start : 02/09/2016 @ 11:14
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:24
Location : First Floor-A117 Main Received: 02/17/2016 @ 11:07
Radon Level : 0.8 pCi/L Analyzed: 02/18/2016 @ 13:54
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2403798 Test Start : 02/09/2016 @ 10:33
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:04
Location : First Floor-B110 Received: 02/17/2016 @ 11:07
Radon Level : 0.7 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2403800 Test Start : 02/09/2016 @ 09:59
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:34
Location : First Floor-G113 Received: 02/17/2016 @ 11:06
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 14:31
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2403809 Test Start : 02/09/2016 @ 11:29
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:34
Location : Second Floor-C205 Received: 02/17/2016 @ 11:07
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 16:45
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2403827 Test Start : 02/09/2016 @ 10:54
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:08
Location : First Floor-B114 Received: 02/17/2016 @ 11:07
Radon Level : 0.4 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2403828 Test Start : 02/09/2016 @ 11:24
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:30
Location : Second Floor-B209 Received: 02/17/2016 @ 11:07
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2403845 Test Start : 02/09/2016 @ 09:23
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:09
Location : First Floor-Conf Rm Received: 02/17/2016 @ 11:06
Radon Level : 0.9 pCi/L Analyzed: 02/18/2016 @ 16:14
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2404162 Test Start : 02/09/2016 @ 11:01
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:15
Location : First Floor-B122 Received: 02/17/2016 @ 11:07
Radon Level : 0.5 pCi/L Analyzed: 02/18/2016 @ 13:08
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2404270 Test Start : 02/09/2016 @ 11:00
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:13
Location : First Floor-B119 Received: 02/17/2016 @ 11:07
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 12:52
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2404274 Test Start : 02/09/2016 @ 10:32
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 12:04
Location : First Floor-B113 Received: 02/17/2016 @ 11:07
Radon Level : 0.2 pCi/L Analyzed: 02/18/2016 @ 13:23
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2404431 Test Start : 02/09/2016 @ 09:40
Canister Type : Charcoal Canister 3 inch Test Stop : 02/12/2016 @ 11:18
Location : First Floor-E103 Received: 02/17/2016 @ 11:06
Radon Level : 0.1 pCi/L Analyzed: 02/18/2016 @ 14:09
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/17/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Willink Middle School
Test Location: 900 Publishers Parkway
Webster, NY 14580-

Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

*Andreas C. George*

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201