



January 10, 2017

Mr Blaine Cunningham
Director of Facilities
Webster Central School District

RE: Drinking Water - Independent Testing and Analysis- Interim Report

Dear Mr. Cunningham,

Attached to this letter you will find the interim results for the second round of water testing that we have done in each of your facilities. Initially we only tested 10 locations per school building. New York State has since made it mandatory that every potable source be tested. The sampling and reporting was done within the requirements set by New York State and the EPA 3Ts Guidance document. In the following pages, we have summarized only the elevated samples and reported the results in parts per billion (ppb). See the lab reports for a listing of every sample collected.

Every fixture that was elevated (above 15 ppb), has been either been taken out of service or has been labeled as non-potable (NP). The elevated fixtures are currently in the process of being assessed, then serviced or replaced prior to retesting. Drinking fountains and sinks that are most likely to be used for consumption are currently being prioritized. The tables below have some of the follow-up testing listed in the right hand column. "TBT" indicates that the fixture is to be tested in the future and to remain either out-of-service or labeled non-potable until satisfactory results are obtained.

If you or anyone has questions, do not hesitate to contact me

Sincerely,

Darren Yehl
President
Yehl Environmental Incorporated
515 State Street
Rochester, NY 14608

Dewitt Elementary School	Initial Result (ppb)	Follow up Result (ppb)
Kitchen Dish Sink	28.3	TBT
Kitchen South Sink	25.1	3.2
Kitchen South Left Sink	17.8	11.7
115 Hall Drinking Fountain	15.5	12.3
Library Sink	591.0	13.7
K1 Island Sink	22.4	9.12
K1 Island Drinking Fountain	16.0	10.3
102 Sink	19.5	5.90
106 Sink	26.6	11.8
106 Drinking Fountain	29.3	11.4
201 Sink	39.2	11.7
202 Sink	22.7	9.77
202 Drinking Fountain	17.6	12.5
203 Drinking Fountain	19.2	7.10
204 Drinking Fountain	19.0	13.2
205 Sink	18.3	14.2
205 Drinking Fountain	28.3	3.03
206 Sink	21.0	9.46
207 Sink	18.4	11.9
208 Sink	55.6	7.36
208 Drinking Fountain	44.3	4.06
209 Sink	32.2	12.2
209 Drinking Fountain	85.6	9.14
210 Sink	21.1	6.27
210 Drinking Fountain	15.5	3.07
212 Sink	108	TBT
214 Sink	145.0	TBT

Klem North Elementary School	Initial Result (ppb)	Follow-up Result (ppb)	
Psychologist Sink	17.2	TBT	
Assistant Principal Sink	57.2	TBT	
Library Sink	28.9	TBT	
Music Sink	21.3	TBT	
Centrum East Sink	177	TBT	
101 Island Sink	15.7	TBT	
102 Porcelain Sink	24.6	TBT	
105 Sink	17.3	TBT	
109 Sink	24.1	TBT	
201 Sink	16.0	TBT	
202 Sink	19.6	TBT	
202 Drinking Fountain	28.4		6.6
205 Sink	183	TBT	
206 Sink	19.9	TBT	
207 Drinking Fountain	53.7	TBT	
209 Sink	19.3	TBT	

Klem South Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Kitchen #3 Sink	18.5	TBT
Nurse #2 Sink	16	5
Cafeteria Drinking Fountain	22.4	1.0
201 Sink	16.3	TBT
301 Sink	86.3	TBT
301 Drinking Fountain	27.9	3.1
407 Sink	16.9	TBT
408 #3 Sink	25.7	TBT
502 Sink	38.5	TBT
503 Sink	31.5	TBT
706 Sink	22.6	TBT
707 Sink	16.9	TBT
709 Sink	23.5	TBT
805 Hallway Drinking Fountain	24.4	11.7
807 Sink	48.6	TBT

Plank North Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
110 Sink	25.9	TBT
111 Sink	21.5	TBT
117 Sink	28.6	TBT
118 Sink	17.4	TBT
201 Sink	50.5	TBT
202 Sink	23.5	7.79
203 Sink	45.5	8.51
209 Sink	23.2	4.76
202 Drinking Fountain	22.4	2.55
203 Drinking Fountain	49.2	1.51

Plank South Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Kitchen #3 Sink	29.3	TBT
Library Office Sink	21.8	TBT
Music Sink	44.5	TBT
Art North Sink	16	TBT
607 Sink	19	TBT
609 Sink	15.6	TBT
1 Sink	17.6	TBT

Schlegel Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Kitchen #2 Sink	19.7	7.86
Kitchen #3 Sink	36.3	NP
Cafeteria Drinking Fountain	20.8	1.0
807 Sink	35.0	TBT
Art #3 Sink	39.8	TBT
304 Drinking Fountain	16.6	2.53
502 Sink	42.1	TBT

State Road Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Main Office Sink	18.9	2.13
Library Sink	70.3	TBT
102 East Sink	59.4	TBT
103 Sink	30.4	TBT
107 Sink	16.4	TBT
108 Sink	62.1	TBT
112 Sink	31.3	TBT
210 Sink	25.3	TBT
206 Sink	29	TBT
214 Sink	23.9	TBT

Willink Middle School	Initial Result (ppb)	Follow-up Result (ppb)
D103 Drinking Fountain	25	2.68
Kitchen Coffee	16	7.31
A206 Left Sink	42	NP
A206 Middle Sink	35	NP
A206 Right Sink	52	NP
A207 Left Sink	51	NP
A207 Middle Sink	32	NP
A207 Right Sink	37	NP
B206 Left Sink	32	NP
B206 Middle Sink	26	NP
B206 Right Sink	53	NP
B207 Left Sink	33	NP
B207 Middle Sink	25	NP
B207 Right Sink	33	NP
C207 Left Sink	52	NP
C207 Middle Sink	33	NP
C207 Right Sink	32	NP
C206 Left Sink	24	NP
C206 Middle Sink	44	NP
C206 Right Sink	43	NP

PDC Building	Initial Result (ppb)	Follow-up Result (ppb)
PDC Coffee Left	25	1.0

Schroeder High School	Initial Result (ppb)	Follow-up Result (ppb)
W2 Sink	16	TBT
N101 Sink	25	TBT
N4 Sink	36	TBT
W5/W7 Sink	18	TBT
N9 Sink	15	TBT
W22 Sink	24	TBT
South West Kitchen Sink	22	TBT
South East #2 Kitchen Sink	41	TBT
#3 Kitchen Sink	91	5.16
W28 Faculty Coffee	35	13.4
N18 Sink	65	2.63
E12 Left Sink	30	TBT
W228 Sink	21	TBT
E234 Drinking Fountain	94	TBT
W227 Drinking Fountain	18	TBT
Math Sink	18	TBT
E19/E21 Back Sink	97	TBT
E23 Back Sink	22	TBT
E2 Sink	39	TBT
E14 Sink	39	TBT
W200 Drinking Fountain	32	TBT
W221 Sink	20	TBT
E202 Sink	15	TBT
W201 Sink	41	TBT

Spry Middle School	Initial Result (ppb)	Follow-up Result (ppb)
129 Left Sink	70	TBT
129 Middle Sink	46	TBT
129 Right Sink	1000	TBT
131 Left Sink	29	TBT
131 Middle Sink	88	TBT
131 Right Sink	58	TBT
Conference Room A Sink	18	TBT
Superintendent Sink	64	TBT
326 #1 Sink	23	1.63
326 #2 Sink	32	1.34

Thomas High School	Initial Result (ppb)	Follow-up Result (ppb)
West Cafe Sink	44	TBT
329 Sink	700	TBT
336 West Sink	15	TBT
340 South West Sink	29	TBT
340 East Sink	200	TBT
340 West Sink	39	TBT
338 Back Sink	26	TBT
Main Office Sink	33	TBT
248 Sink	46	TBT