



June 8, 2017

Mr Blaine Cunningham
Director of Facilities
Webster Central School District

RE: Drinking Water - Independent Testing and Analysis- Interim Report

Dear Mr. Cunningham,

Attached to this letter you will find the interim results for the first, second, and third round of water testing that we have done in each of your facilities. Initially we only tested 10 locations per school building. All of the elevated samples from the first round have been remediated and are now within acceptable ranges (see below). New York State has since made it mandatory that every potable source be tested. The sampling and reporting was completed within the requirements set by New York State and the EPA 3Ts Guidance document. In the following pages, we have summarized only the elevated samples and reported the results in parts per billion (ppb) with the follow up testing to date. See the lab reports for a listing of every sample collected. Every fixture that was elevated (above 15 ppb), has either been taken out of service or has been labeled as non-potable (NP). The elevated fixtures are currently in the process of being assessed, then serviced or replaced prior to retesting. Drinking fountains and sinks that are most likely to be used for consumption are currently being prioritized. The tables below have all of the follow-up testing listed in the right hand column. "TBT" indicates that the fixture is "to be tested" in the future and to remain either out-of-service or labeled non-potable until satisfactory results are obtained. The third round of testing involves the several sources originally identified as non-potable, such as restroom sinks and science laboratories.

If you or anyone has questions, do not hesitate to contact me

Sincerely,

Darren Yehl
President
Yeh Environmental Incorporated
515 State Street
Rochester, NY 14608

Dewitt Elementary School	Initial Result (ppb)	Follow up Result (ppb)
Kitchen Dish Sink	28.3	TBT
Kitchen South Sink	25.1	3.2
Kitchen South Left Sink	17.8	11.7
115 Hall Drinking Fountain	15.5	12.3
Library Sink	591.0	13.7
K1 Island Sink	22.4	9.12
K1 Island Drinking Fountain	16.0	10.3
102 Sink	19.5	5.90
106 Sink	26.6	11.8
106 Drinking Fountain	29.3	11.4
201 Sink	39.2	11.7
202 Sink	22.7	9.77
202 Drinking Fountain	17.6	12.5
203 Drinking Fountain	19.2	7.10
204 Drinking Fountain	19.0	13.2
205 Sink	18.3	14.2
205 Drinking Fountain	28.3	3.03
206 Sink	21.0	9.46
207 Sink	18.4	11.9
208 Sink	55.6	7.36
208 Drinking Fountain	44.3	4.06
209 Sink	32.2	12.2
209 Drinking Fountain	85.6	9.14
210 Sink	21.1	6.27
210 Drinking Fountain	15.5	3.07
212 Sink	108	14.8
214 Sink	145.0	9.0

Klem North Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Teacher Lounge Sink	31.2	14.3
Psychologist Sink	17.2	TBT
Assistant Principal Sink	57.2	3.4
Library Sink	28.9	8.4
Music Sink	21.3	6.0
Centrum East Sink	177	5.4
101 Island Sink	15.7	4.1
102 Porcelain Sink	24.6	6.1
105 Sink	17.3	3.5
109 Sink	24.1	2.6
201 Sink	16.0	TBT
202 Sink	19.6	4.0
202 Drinking Fountain	28.4	6.6
205 Sink	183	4.2
206 Sink	19.9	TBT
207 Drinking Fountain	53.7	8
209 Sink	19.3	4.0

Klem South Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Kitchen #3 Sink	18.5	TBT
Nurse #2 Sink	16	5
Cafeteria Drinking Fountain	22.4	1.0
201 Sink	16.3	13.8
301 Sink	86.3	2.1
301 Drinking Fountain	27.9	3.1
407 Sink	16.9	5.4
408 #3 Sink	25.7	TBT
502 Sink	38.5	13.6
503 Sink	31.5	3.2
706 Sink	22.6	TBT
707 Sink	16.9	8.6
709 Sink	23.5	7.3
805 Hallway Drinking Fountain	24.4	11.7
807 Sink	48.6	TBT

Plank North Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Nurse Sink	21	9.5
209 Drinking Fountain	16.9	8.0
117 Drinking Fountain	19	11.0
110 Sink	25.9	2.1
111 Sink	21.5	5.0
117 Sink	28.6	5.6
118 Sink	17.4	TBT
201 Sink	50.5	3.5
202 Sink	23.5	7.79
203 Sink	45.5	8.51
209 Sink	23.2	4.76
202 Drinking Fountain	22.4	2.55
203 Drinking Fountain	49.2	1.51

Plank South Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Kitchen #3 Sink	29.3	TBT
Library Office Sink	21.8	8.5
Music Sink	44.5	TBT
Art North Sink	16	TBT
607 Sink	19	3.2
609 Sink	15.6	4.2
1 Sink	17.6	6.7

Schlegel Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Kitchen #2 Sink	19.7	7.86
Kitchen #3 Sink	36.3	NP
Cafeteria Drinking Fountain	20.8	1.0
807 Sink	35.0	TBT
Art #3 Sink (storage)	39.8	2.9
304 Drinking Fountain	16.6	2.53
502 Sink	42.1	8.1
Mens Room Art Right Sink	16.5	TBT

State Road Elementary School	Initial Result (ppb)	Follow-up Result (ppb)
Main Office Sink	18.9	2.13
Library Sink	70.3	TBT
102 East Sink	59.4	TBT
103 Sink	30.4	5.3
107 Sink	16.4	3.9
108 Sink	62.1	1.9
112 Sink	31.3	3.2
210 Sink	25.3	TBT
206 Sink	29	5.3
214 Sink	23.9	3.3

Willink Middle School	Initial Result (ppb)	Follow-up Result (ppb)
D103 Drinking Fountain	25	2.68
Kitchen Coffee	16	7.31
A206 Left Sink (Science)	42	10.6
A206 Middle Sink (Science)	35	11.5
A206 Right Sink (Science)	52	12.9
A207 Left Sink (Science)	51	NP
A207 Middle Sink (Science)	32	NP
A207 Right Sink (Science)	37	NP
B206 Left Sink (Science)	32	NP
B206 Middle Sink (Science)	26	12.6
B206 Right Sink (Science)	53	NP
B207 Left Sink (Science)	33	NP
B207 Middle Sink (Science)	25	10.2
B207 Right Sink (Science)	33	NP
C207 Left Sink (Science)	52	7.3
C207 Middle Sink (Science)	33	13.2
C207 Right Sink (Science)	32	NP
C206 Left Sink (Science)	24	8.2
C206 Middle Sink (Science)	44	14.6
C206 Right Sink (Science)	43	NP

PDC Building	Initial Result (ppb)	Follow-up Result (ppb)
PDC Coffee Left	25	1.0

Schroeder High School	Initial Result (ppb)	Follow-up Result (ppb)
W3 Hall Drinking Fountain	24.6	8.9
Music Hall Drinking Fountain	16.2	8.23
W28 Drinking Fountain	33.2	1.0
W2 Sink	16	TBT
N101 Sink	25	TBT
N4 Sink	36	TBT
W5/W7 Sink	18	TBT
N9 Sink	15	TBT
W22 Sink	24	TBT
South West Kitchen Sink	22	TBT
South East #2 Kitchen Sink	41	TBT
#3 Kitchen Sink	91	5.16
W28 Faculty Coffee	35	13.4
N18 Sink	65	2.63
E12 Left Sink	30	TBT
W228 Sink	21	TBT
E234 Drinking Fountain	94	TBT
W227 Drinking Fountain	18	TBT
Math Sink	18	TBT
E19/E21 Back Sink	97	TBT
E23 Back Sink	22	TBT
E2 Sink	39	TBT
E14 Sink	39	TBT
W200 Drinking Fountain	32	TBT
W221 Sink	20	TBT
E202 Sink	15	TBT
W201 Sink	41	TBT

Spry Middle School	Initial Result (ppb)	Follow-up Result (ppb)
3rd Floor File Room Hall Drinking Fountain	17.5	1.0
129 Left Sink	70	1.6
129 Middle Sink	46	2.1
129 Right Sink	1000	2.9
131 Left Sink	29	1.6
131 Middle Sink	88	2.1
131 Right Sink	58	1.9
Conference Room A Sink	18	1.5
Superintendent Sink	64	13.6
326 #1 Sink	23	1.63
326 #2 Sink	32	1.34

Thomas High School	Initial Result (ppb)	Follow-up Result (ppb)
West Cafe Sink	44	TBT
329 Sink	700	TBT
336 West Sink	15	TBT
340 South West Sink	29	TBT
340 East Sink	200	TBT
340 West Sink	39	TBT
338 Back Sink	26	TBT
Main Office Sink	33	TBT
248 Sink	46	TBT
Boys Locker Sink Left	134	NP
452 Sink	16	NP
454 Faculty Sink	15.1	NP
Field House Women's Middle Sink	95.2	NP
128 Faculty Sink	17.1	NP
107 Sink	19.6	NP